

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Waldo Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
57-01A Boys Locker Room Drinking Fountain	8/5/16 5:59	8/15/16 9:28	608083801	LEAD	< 1 PPB	15 PPB
57-02A Hall Outside Boys Locker Room Drinking Fountain 1	8/5/16 6:03	8/15/16 9:28	608083802	LEAD	< 1 PPB	15 PPB
57-03A Gymnasium Drinking Fountain	8/5/16 6:07	8/15/16 9:28	608083803	LEAD	< 1 PPB	15 PPB
57-04A Storage Room (301/302) Sink Faucet	8/5/16 6:09	8/15/16 9:28	608083804	LEAD	2 PPB	15 PPB
57-05A Storage Room between 303 & 305 Sink Faucet	8/5/16 6:16	8/15/16 9:28	608083805	LEAD	6 PPB	15 PPB
57-06A Hallway Drinking Fountain 2	8/5/16 6:18	8/15/16 9:28	608083806	LEAD	< 1 PPB	15 PPB
57-07A Classroom 305 Sink Faucet	8/5/16 6:21	8/15/16 9:28	608083807	LEAD	2 PPB	15 PPB
57-08A Classroom 305 Sink Faucet	8/5/16 6:21	8/15/16 9:29	608083808	LEAD	3 PPB	15 PPB
57-09A Classroom 308 Sink Faucet	8/5/16 6:26	8/15/16 9:29	608083809	LEAD	4 PPB	15 PPB
57-10A Classroom 308 Drinking Fountain	8/5/16 6:26	8/15/16 9:30	608083810	LEAD	2 PPB	15 PPB
57-11A Classroom 307 Sink Faucet	8/5/16 6:28	8/15/16 9:30	608083811	LEAD	3 PPB	15 PPB
57-12A Classroom 310 Sink Faucet	8/5/16 6:30	8/15/16 9:31	608083812	LEAD	3 PPB	15 PPB
57-13A Classroom 310 Drinking Fountain	8/5/16 6:30	8/15/16 9:31	608083813	LEAD	< 1 PPB	15 PPB
57-14A Hall between CR 307, 309 Drinking Fountain 3	8/5/16 6:34	8/15/16 9:31	608083814	LEAD	< 1 PPB	15 PPB
57-15A Classroom 311 Home Economics Sink Faucet 1	8/5/16 6:42	8/15/16 9:31	608083815	LEAD	< 1 PPB	15 PPB
57-16A Classroom 311 Home Economics Sink Faucet 2	8/5/16 6:42	8/15/16 9:31	608083816	LEAD	< 1 PPB	15 PPB
57-17A Classroom 311 Home Economics Sink Faucet 3	8/5/16 6:43	8/15/16 9:31	608083817	LEAD	< 1 PPB	15 PPB
57-18A Classroom 311 Home Economics Sink Faucet 4	8/5/16 6:43	8/15/16 9:31	608083818	LEAD	< 1 PPB	15 PPB
57-19A Classroom 311 Home Economics Sink Faucet 5	8/5/16 6:43	8/15/16 9:31	608083819	LEAD	2 PPB	15 PPB
57-20A Classroom 311 Home Economics Sink Faucet 6	8/5/16 6:44	8/15/16 9:32	608083820	LEAD	< 1 PPB	15 PPB
57-21A Classroom 311 Home Economics Sink Faucet 7	8/5/16 6:44	8/15/16 9:32	608083821	LEAD	< 1 PPB	15 PPB
57-22A Girls Locker Room Drinking Fountain	8/5/16 7:01	8/15/16 9:32	608083822	LEAD	1 PPB	15 PPB
57-23A Hall across from Classroom 202 Drinking Fountain 4	8/5/16 6:54	8/15/16 9:32	608083823	LEAD	< 1 PPB	15 PPB
57-24A Hall by Room 214 Drinking Fountain 5	8/5/16 6:57	8/15/16 9:32	608083824	LEAD	2 PPB	15 PPB
57-25A Classroom by 216 Drinking Fountain 1	8/5/16 7:01	8/15/16 9:32	608083825	LEAD	4 PPB	15 PPB
57-26A Classroom by 216 Drinking Fountain 2	8/5/16 7:02	8/15/16 9:32	608083826	LEAD	1 PPB	15 PPB
57-27A Hallway across from 112 Water Fountain 6	8/5/16 5:59	8/15/16 9:32	608083827	LEAD	2 PPB	15 PPB
57-28A Classroom 112 Sink Faucet near Door	8/5/16 7:10	8/15/16 9:32	608083828	LEAD	< 1 PPB	15 PPB
57-29A Classroom 112 Sink Drinking Fountain	8/5/16 7:10	8/15/16 9:32	608083829	LEAD	< 1 PPB	15 PPB
57-30A AV Room Sink Faucet	8/5/16 7:14	8/15/16 9:33	608083830	LEAD	1 PPB	15 PPB
57-31A Nurses Station Sink Faucet (Office)	8/5/16 7:19	8/15/16 9:33	608083831	LEAD	< 1 PPB	15 PPB
57-32A Faculty Lounge Sink Faucet	8/5/16 7:23	8/15/16 9:33	608083832	LEAD	2 PPB	15 PPB
57-33A Classroom 104 Sink Faucet	8/5/16 7:30	8/15/16 9:33	608083833	LEAD	2 PPB	15 PPB
57-34A Classroom 102 Sink Faucet	8/5/16 7:51	8/15/16 9:33	608083834	LEAD	< 1 PPB	15 PPB
57-35A Hall Refrigerated Drinking Fountain 7	8/5/16 7:35	8/15/16 9:33	608083835	LEAD	< 1 PPB	15 PPB
57-36A Automated Water Bottle Refill	8/5/16 7:36	8/15/16 9:33	608083836	LEAD	< 1 PPB	15 PPB
57-37A Kitchen Sink Faucet (Eye Wash)	8/5/16 7:46	8/15/16 9:33	608083837	LEAD	3 PPB	15 PPB
57-38A Triple Sink Left Faucet	8/5/16 7:47	8/15/16 9:33	608083838	LEAD	1 PPB	15 PPB
57-39A Triple Sink Right Faucet	8/5/16 7:47	8/15/16 9:33	608083839	LEAD	1 PPB	15 PPB
57-40A Ice Maker	8/5/16 7:48	8/15/16 9:35	608083840	LEAD	< 1 PPB	15 PPB
57-41A Kitchen Sink Faucet	8/5/16 7:50	8/15/16 9:35	608083841	LEAD	2 PPB	15 PPB
57-42A Kitchen Produce Sink Faucet	8/5/16 7:51	8/15/16 9:35	608083842	LEAD	< 1 PPB	15 PPB
57-43A Kitchen Sink Faucet	8/5/16 7:52	8/15/16 9:35	608083843	LEAD	1 PPB	15 PPB
57-44A Skullery Sink Faucet	8/5/16 7:53	8/15/16 9:35	608083844	LEAD	2 PPB	15 PPB
57-45A Drinking Fountain Corridor next to Girls Locker Room 8	8/5/16 7:57	8/15/16 9:35	608083845	LEAD	< 1 PPB	15 PPB
57-46A Drinking Fountain outside Gymnasium 9	8/5/16 8:03	8/15/16 9:35	608083846	LEAD	1 PPB	15 PPB
57-47A Drinking Fountain outside Gymnasium 10	8/5/16 8:04	8/15/16 9:35	608083847	LEAD	< 1 PPB	15 PPB
57-48A Drinking Fountain in Music Room outside Gymnasium	8/5/16 8:10	8/15/16 9:35	608083848	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level