

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-01A Cafeteria Drinking Fountain	7/22/2016 11:53	8/2/2016	44120	LEAD	2 PPB	15 PPB
59-02A Kitchen Sink Faucet (west wall)	7/22/2016 11:55	8/2/2016	44121	LEAD	<1 PPB	15 PPB
59-03A Kitchen Sink Faucet (south wall)	7/22/2016 11:57	8/2/2016	44122	LEAD	1 PPB	15 PPB
59-04A Cafeteria Hall Drinking Fountain	7/22/2016 11:59	8/2/2016	44123	LEAD	1 PPB	15 PPB
59-05A Room 19 Sink Faucet	7/22/2016 12:01	8/2/2016	44124	LEAD	11 PPB	15 PPB
59-06A Room 19 Drinking Fountain	7/22/2016 12:03	8/2/2016	44125	LEAD	<1 PPB	15 PPB
59-07A Room 18 Sink Faucet	7/22/2016 12:05	8/2/2016	44126	LEAD	7 PPB	15 PPB
59-08A Room 18 Drinking Fountain	7/22/2016 12:07	8/2/2016	44127	LEAD	<1 PPB	15 PPB
59-09A Room 17 Sink Faucet	7/22/2016 12:09	8/2/2016	44128	LEAD	2 PPB	15 PPB
59-10A Room 17 Drinking Fountain	7/22/2016 12:10	8/2/2016	44129	LEAD	<1 PPB	15 PPB
59-11A Room 1 Sink Faucet	7/22/2016 12:13	8/2/2016	44130	LEAD	6 PPB	15 PPB
59-12A Room 1 Drinkiing Fountain	7/22/2016 12:15	8/2/2016	44131	LEAD	2 PPB	15 PPB
59-13A Office Hallway Drinking Fountain (left)	7/22/2016 12:17	8/2/2016	44132	LEAD	2 PPB	15 PPB
59-14A Office Hallway Drinking Fountain (right)	7/22/2016 12:19	8/2/2016	44133	LEAD	2 PPB	15 PPB
59-15A Main Office Sink Faucet	7/22/2016 12:21	8/2/2016	44134	LEAD	2 PPB	15 PPB
59-16A Health Room Sink Faucet	7/22/2016 12:23	8/2/2016	44135	LEAD	4 PPB	15 PPB
59-17A Staff Room Sink Faucet	7/22/2016 12:25	8/2/2016	44136	LEAD	2 PPB	15 PPB
59-18A Room 2 Sink Faucet	7/22/2016 12:27	8/2/2016	44137	LEAD	1 PPB	15 PPB
59-19A Room 16 Sink Faucet	7/22/2016 12:29	8/2/2016	44138	LEAD	9 PPB	15 PPB
59-20A Room 16 Drinkinkg Fountain	7/22/2016 12:31	8/2/2016	44139	LEAD	2 PPB	15 PPB
59-21A Room 13 Sink Faucet	7/22/2016 12:33	8/2/2016	44140	LEAD	5 PPB	15 PPB
59-22A Room 13 Drinking Fountain	7/22/2016 12:35	8/2/2016	44141	LEAD	2 PPB	15 PPB
59-23A Room 15 Sink Faucet	7/22/2016 12:37	8/2/2016	44142	LEAD	4 PPB	15 PPB
59-24A Room 15 Drinking Fountain	7/22/2016 12:39	8/2/2016	44143	LEAD	<1 PPB	15 PPB
59-25A Room 14 Sink Faucet	7/22/2016 12:41	8/2/2016	44144	LEAD	12 PPB	15 PPB
59-26A Room 14 Drinking Fountain	7/22/2016 12:43	8/2/2016	44145	LEAD	<1 PPB	15 PPB
59-27A Library Sink Faucet	7/22/2016 12:45	8/2/2016	44146	LEAD	8 PPB	15 PPB
59-28A Room 12 Sink Faucet	7/22/2016 12:47	8/2/2016	44147	LEAD	2 PPB	15 PPB
59-29A Room 12 Drinking Fountain	7/22/2016 12:49	8/2/2016	44148	LEAD	4 PPB	15 PPB
59-30A Media Room Sink Faucet	7/22/2016 12:51	8/2/2016	44149	LEAD	3 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-31A Media Room Drinking Fountain	7/22/2016 12:53	8/2/2016	44150	LEAD	4 PPB	15 PPB
59-32A Room 11 Sink Faucet	7/22/2016 12:55	8/2/2016	44151	LEAD	4 PPB	15 PPB
59-33A Room 11 Drinking Fountain	7/22/2016 12:57	8/2/2016	44152	LEAD	5 PPB	15 PPB
59-34A Room 4 Sink Faucet	7/22/2016 12:59	8/2/2016	44153	LEAD	3 PPB	15 PPB
59-35A Room 4 Drinking Fountain	7/22/2016 13:01	8/2/2016	44154	LEAD	2 PPB	15 PPB
59-36A Room 10 Sink Faucet	7/22/2016 13:03	8/2/2016	44155	LEAD	5 PPB	15 PPB
59-37A Room 10 Drinking Fountain	7/22/2016 13:05	8/2/2016	44156	LEAD	3 PPB	15 PPB
59-38A Room 5 Sink Faucet	7/22/2016 13:07	8/2/2016	44157	LEAD	4 PPB	15 PPB
59-39A Room 5 Drinking Fountain	7/22/2016 13:09	8/2/2016	44158	LEAD	4 PPB	15 PPB
59-40A Room 6 Sink Faucet	7/22/2016 13:11	8/2/2016	44159	LEAD	5 PPB	15 PPB
59-41A Room 6 Drinking Fountain	7/22/2016 13:13	8/2/2016	44160	LEAD	16 PPB	15 PPB
59-42A Room 9 Sink Faucet	7/22/2016 13:15	8/2/2016	44161	LEAD	4 PPB	15 PPB
59-43A Room 9 Drinking Fountain	7/22/2016 13:17	8/2/2016	44162	LEAD	1 PPB	15 PPB
59-44A Room 7 Sink Faucet	7/22/2016 13:20	8/2/2016	44163	LEAD	17 PPB	15 PPB
59-45A Room 7 Drinking Fountain	7/22/2016 13:22	8/2/2016	44164	LEAD	2 PPB	15 PPB
59-46A Room 8 Sink Faucet	7/22/2016 13:24	8/2/2016	44165	LEAD	2 PPB	15 PPB
59-47A Room 8 Drinking Fountain	7/22/2016 13:26	8/2/2016	44166	LEAD	<1 PPB	15 PPB
59-48A Gymnasium Drinking Fountain	7/22/2016 13:30	8/2/2016	44167	LEAD	<1 PPB	15 PPB
59-49A Music Room Sink Faucet	7/22/2016 13:32	8/2/2016	44168	LEAD	8 PPB	15 PPB
59-50A Music Room Drinking Fountain	7/22/2016 13:34	8/2/2016	44169	LEAD	1 PPB	15 PPB
59-51A Main Corridor Outside Media Center Drinking Fountain (left)	7/22/2016 13:45	8/2/2016	44170	LEAD	<1 PPB	15 PPB
59-52A Main Corridor Outside Media Center Drinking Fountain (right)	7/22/2016 13:47	8/2/2016	44171	LEAD	1 PPB	15 PPB
59-53A Main Corridor Near Room 6 Drinking Fountian	7/22/2016 13:49	8/2/2016	44172	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-41B Room 6 Drinking Fountain	7/22/2016 13:14	9/6/2016	52947	LEAD	<1 PPB	15 PPB
59-44B Room 7 Sink Faucet	7/22/2016 13:21	9/6/2016	52948	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-41C Room 6 Drinking Fountain	10/27/2016 5:39	10/28/2016	65856	LEAD	<1 PPB	15 PPB
59-44C Room 7 Sink Faucet	10/27/2016 5:41	10/28/2016	65857	LEAD	5 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level