

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Weddle Elementary School

| Sample Identification # and Location | Date Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level | |
|--------------------------------------|--------------------------------------|---------------|--------------|-------------|---------|--------------|---------|
| 60-01A | Gymnasium Hall Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-01A | COPPER | 0.4 PPM | 1.3 PPM |
| 60-02A | Kitchen Sink Faucet (Large) | 7/23/2016 | 7/30/2016 | 1607A90-02A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-03A | Kitchen Sink Faucet (Small) | 7/23/2016 | 7/30/2016 | 1607A90-03A | COPPER | 0.5 PPM | 1.3 PPM |
| 60-04A | Music Room Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-04A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-05A | Staff Room Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-05A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-06A | Nurse's Room Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-06A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-07A | A-Pod Hall Drinking Fountain (Left) | 7/23/2016 | 7/30/2016 | 1607A90-07A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-08A | A-Pod Hall Drinking Fountain (Right) | 7/23/2016 | 7/30/2016 | 1607A90-08A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-09A | A-3 Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-09A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-10A | A-3 Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-10A | COPPER | 0.4 PPM | 1.3 PPM |
| 60-11A | A-5 Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-11A | COPPER | 0.4 PPM | 1.3 PPM |
| 60-12A | A-5 Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-12A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-13A | A-7 Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-13A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-14A | A-7 Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-14A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-15A | A-4 Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-15A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-16A | A-4 Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-16A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-17A | A-2 Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-17A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-18A | A-2 Drinking Fountain | 7/23/2016 | 7/30/2016 | 1607A90-18A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-19A | Library Work Room Sink Faucet | 7/23/2016 | 7/30/2016 | 1607A90-19A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-20A | B-Pod Hall Drinking Fountain (Left) | 7/23/2016 | 7/30/2016 | 1607A90-20A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-21A | B-Pod Hall Drinking Fountain (Right) | 7/23/2016 | 7/30/2016 | 1607A90-21A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-22A | B-1 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-22A | COPPER | 0.4 PPM | 1.3 PPM |
| 60-23A | B-1 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-23A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-24A | B-3 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-24A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-25A | B-3 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-25A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-26A | B-5 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-26A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-27A | B-5 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-27A | COPPER | 0.3 PPM | 1.3 PPM |

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Weddle Elementary School

| | | | | | | | |
|--------|--------------------------------------|-----------|-----------|-------------|--------|---------|---------|
| 60-28A | B-6 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-28A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-29A | B-6 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-29A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-30A | B-4 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-30A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-31A | B-4 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-31A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-32A | B-2 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-32A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-33A | B-2 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-33A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-34A | C-Pod Hall Drinking Fountain (Left) | 7/23/2016 | 7/31/2016 | 1607A90-34A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-35A | C-Pod Hall Drinking Fountain (Right) | 7/23/2016 | 7/31/2016 | 1607A90-35A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-36A | C-1 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-36A | COPPER | 0.4 PPM | 1.3 PPM |
| 60-37A | C-1 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-37A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-38A | C-3 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-38A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-39A | C-3 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-39A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-40A | C-5 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-40A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-41A | C-5 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-41A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-42A | C-6 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-42A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-43A | C-6 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-43A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-44A | C-4 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-44A | COPPER | 0.2 PPM | 1.3 PPM |
| 60-45A | C-4 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-45A | COPPER | 0.3 PPM | 1.3 PPM |
| 60-46A | C-2 Sink Faucet | 7/23/2016 | 7/31/2016 | 1607A90-46A | COPPER | 0.2 PPM | 1.3 PPM |
| 60-47A | C-2 Drinking Fountain | 7/23/2016 | 7/31/2016 | 1607A90-47A | COPPER | 0.3 PPM | 1.3 PPM |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level