

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Weddle Elementary School

Sample Identification # and Location	Date Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
60-01A Gymnasium Hall Drinking Fountain	7/23/2016	7/30/2016	1607A90-01A	LEAD	<1.0 PPB	15 PPB
60-02A Kitchen Sink Faucet (Large)	7/23/2016	7/30/2016	1607A90-02A	LEAD	1 PPB	15 PPB
60-03A Kitchen Sink Faucet (Small)	7/23/2016	7/30/2016	1607A90-03A	LEAD	1 PPB	15 PPB
60-04A Music Room Sink	7/23/2016	7/30/2016	1607A90-04A	LEAD	1 PPB	15 PPB
60-05A Staff Room Sink Faucet	7/23/2016	7/30/2016	1607A90-05A	LEAD	1 PPB	15 PPB
60-06A Nurse's Room Sink Faucet	7/23/2016	7/30/2016	1607A90-06A	LEAD	1 PPB	15 PPB
60-07A A-Pod Hall Drinking Fountain (Left)	7/23/2016	7/30/2016	1607A90-07A	LEAD	<1.0 PPB	15 PPB
60-08A A-Pod Hall Drinking Fountain (Right)	7/23/2016	7/30/2016	1607A90-08A	LEAD	<1.0 PPB	15 PPB
60-09A A-3 Sink Faucet	7/23/2016	7/30/2016	1607A90-09A	LEAD	<1.0 PPB	15 PPB
60-10A A-3 Drinking Fountain	7/23/2016	7/30/2016	1607A90-10A	LEAD	1 PPB	15 PPB
60-11A A-5 Sink Faucet	7/23/2016	7/30/2016	1607A90-11A	LEAD	2 PPB	15 PPB
60-12A A-5 Drinking Fountain	7/23/2016	7/30/2016	1607A90-12A	LEAD	1 PPB	15 PPB
60-13A A-7 Sink Faucet	7/23/2016	7/30/2016	1607A90-13A	LEAD	<1.0 PPB	15 PPB
60-14A A-7 Drinking Fountain	7/23/2016	7/30/2016	1607A90-14A	LEAD	<1.0 PPB	15 PPB
60-15A A-4 Sink Faucet	7/23/2016	7/30/2016	1607A90-15A	LEAD	1 PPB	15 PPB
60-16A A-4 Drinking Fountain	7/23/2016	7/30/2016	1607A90-16A	LEAD	<1.0 PPB	15 PPB
60-17A A-2 Sink Faucet	7/23/2016	7/30/2016	1607A90-17A	LEAD	1 PPB	15 PPB
60-18A A-2 Drinking Fountain	7/23/2016	7/30/2016	1607A90-18A	LEAD	<1.0 PPB	15 PPB
60-19A Library Work Room Sink Faucet	7/23/2016	7/30/2016	1607A90-19A	LEAD	<1.0 PPB	15 PPB
60-20A B-Pod Hall Drinking Fountain (Left)	7/23/2016	7/30/2016	1607A90-20A	LEAD	<1.0 PPB	15 PPB
60-21A B-Pod Hall Drinking Fountain (Right)	7/23/2016	7/30/2016	1607A90-21A	LEAD	<1.0 PPB	15 PPB
60-22A B-1 Sink Faucet	7/23/2016	7/31/2016	1607A90-22A	LEAD	<1.0 PPB	15 PPB
60-23A B-1 Drinking Fountain	7/23/2016	7/31/2016	1607A90-23A	LEAD	<1.0 PPB	15 PPB
60-24A B-3 Sink Faucet	7/23/2016	7/31/2016	1607A90-24A	LEAD	1 PPB	15 PPB
60-25A B-3 Drinking Fountain	7/23/2016	7/31/2016	1607A90-25A	LEAD	<1.0 PPB	15 PPB
60-26A B-5 Sink Faucet	7/23/2016	7/31/2016	1607A90-26A	LEAD	<1.0 PPB	15 PPB
60-27A B-5 Drinking Fountain	7/23/2016	7/31/2016	1607A90-27A	LEAD	1 PPB	15 PPB
60-28A B-6 Sink Faucet	7/23/2016	7/31/2016	1607A90-28A	LEAD	<1.0 PPB	15 PPB
60-29A B-6 Drinking Fountain	7/23/2016	7/31/2016	1607A90-29A	LEAD	1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Weddle Elementary School

60-30A	B-4 Sink Faucet	7/23/2016	7/31/2016	1607A90-30A	LEAD	<1.0	PPB	15	PPB
60-31A	B-4 Drinking Fountain	7/23/2016	7/31/2016	1607A90-31A	LEAD	<1.0	PPB	15	PPB
60-32A	B-2 Sink Faucet	7/23/2016	7/31/2016	1607A90-32A	LEAD	1	PPB	15	PPB
60-33A	B-2 Drinking Fountain	7/23/2016	7/31/2016	1607A90-33A	LEAD	<1.0	PPB	15	PPB
60-34A	C-Pod Hall Drinking Fountain (Left)	7/23/2016	7/31/2016	1607A90-34A	LEAD	1	PPB	15	PPB
60-35A	C-Pod Hall Drinking Fountain (Right)	7/23/2016	7/31/2016	1607A90-35A	LEAD	<1.0	PPB	15	PPB
60-36A	C-1 Sink Faucet	7/23/2016	7/31/2016	1607A90-36A	LEAD	1	PPB	15	PPB
60-37A	C-1 Drinking Fountain	7/23/2016	7/31/2016	1607A90-37A	LEAD	1	PPB	15	PPB
60-38A	C-3 Sink Faucet	7/23/2016	7/31/2016	1607A90-38A	LEAD	2	PPB	15	PPB
60-39A	C-3 Drinking Fountain	7/23/2016	7/31/2016	1607A90-39A	LEAD	1	PPB	15	PPB
60-40A	C-5 Sink Faucet	7/23/2016	7/31/2016	1607A90-40A	LEAD	1	PPB	15	PPB
60-41A	C-5 Drinking Fountain	7/23/2016	7/31/2016	1607A90-41A	LEAD	1	PPB	15	PPB
60-42A	C-6 Sink Faucet	7/23/2016	7/31/2016	1607A90-42A	LEAD	<1.0	PPB	15	PPB
60-43A	C-6 Drinking Fountain	7/23/2016	7/31/2016	1607A90-43A	LEAD	<1.0	PPB	15	PPB
60-44A	C-4 Sink Faucet	7/23/2016	7/31/2016	1607A90-44A	LEAD	1	PPB	15	PPB
60-45A	C-4 Drinking Fountain	7/23/2016	7/31/2016	1607A90-45A	LEAD	<1.0	PPB	15	PPB
60-46A	C-2 Sink Faucet	7/23/2016	7/31/2016	1607A90-46A	LEAD	1	PPB	15	PPB
60-47A	C-2 Drinking Fountain	7/23/2016	7/31/2016	1607A90-47A	LEAD	<1.0	PPB	15	PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level