

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-01A Gymnasium West Side Drinking Fountain (Left)	7/23/2016 6:15	7/28/2016	43484	LEAD	3 PPB	15 PPB
61-02A Gymnasium West Side Drinking Fountain (Right)	7/23/2016 6:17	7/28/2016	43485	LEAD	1 PPB	15 PPB
61-03A Gymnasium East Side Drinking Fountain (Left)	7/23/2016 6:19	7/28/2016	43486	LEAD	<1 PPB	15 PPB
61-04A Gymnasium East Side Drinking Fountain (Right)	7/23/2016 6:21	7/28/2016	43487	LEAD	<1 PPB	15 PPB
61-05A E115 Training Room Sink Faucet	7/23/2016 6:28	7/28/2016	43488	LEAD	<1 PPB	15 PPB
61-06A E115 Training Room Ice Machine	7/23/2016 6:30	7/28/2016	43489	LEAD	<1 PPB	15 PPB
61-07A Girls Locker Room Drinking Fountain	7/23/2016 6:36	7/28/2016	43490	LEAD	<1 PPB	15 PPB
61-08A Girls Locker Room Bottle Refill Station	7/23/2016 6:38	7/28/2016	43491	LEAD	<1 PPB	15 PPB
61-09A Boys Locker Room Drinking Fountain	7/23/2016 6:40	7/28/2016	43492	LEAD	<1 PPB	15 PPB
61-10A Boys Locker Room Bottle Refill Station	7/23/2016 6:42	7/28/2016	43493	LEAD	<1 PPB	15 PPB
61-11A D-103 Sink Faucet	7/23/2016 6:44	7/28/2016	43494	LEAD	<1 PPB	15 PPB
61-12A Food Lab D-128 Sink Faucet 1	7/23/2016 6:46	7/28/2016	43495	LEAD	<1 PPB	15 PPB
61-13A Food Lab D-128 Sink Faucet 2	7/23/2016 6:48	7/28/2016	43496	LEAD	<1 PPB	15 PPB
61-14A Food Lab D-128 Sink Faucet 3	7/23/2016 6:50	7/28/2016	43497	LEAD	<1 PPB	15 PPB
61-15A Food Lab D-128 Sink Faucet 4	7/23/2016 6:52	7/28/2016	43498	LEAD	<1 PPB	15 PPB
61-16A Food Lab D-128 Sink Faucet 5	7/23/2016 6:54	7/28/2016	43499	LEAD	<1 PPB	15 PPB
61-17A Food Lab D-128 Sink Faucet 6	7/23/2016 6:56	7/28/2016	43500	LEAD	<1 PPB	15 PPB
61-18A D Hall Drinking Fountain (Left)	7/23/2016 6:58	7/28/2016	43501	LEAD	<1 PPB	15 PPB
61-19A D Hall Drinking Fountain (Middle)	7/23/2016 7:00	7/28/2016	43502	LEAD	<1 PPB	15 PPB
61-20A D Hall Drinking Fountain (Right)	7/23/2016 7:02	7/28/2016	43503	LEAD	1 PPB	15 PPB
61-21A D Hall Bottle Refill Station	7/23/2016 7:04	7/28/2016	43504	LEAD	<1 PPB	15 PPB
61-22A D-134 Sink Faucet	7/23/2016 7:06	7/28/2016	43505	LEAD	<1 PPB	15 PPB
61-23A D-107 Sink Faucet	7/23/2016 7:08	7/28/2016	43506	LEAD	<1 PPB	15 PPB
61-24A Kitchen Sink Faucet Across From Freezer	7/23/2016 7:10	7/28/2016	43507	LEAD	3 PPB	15 PPB
61-25A Kitchen Sink Faucet (Left) Across From Dish Washer	7/23/2016 7:12	7/28/2016	43508	LEAD	2 PPB	15 PPB
61-26A Kitchen Sink Faucet (Right) Across From Dish Washer	7/23/2016 7:14	7/28/2016	43509	LEAD	3 PPB	15 PPB
61-27A Kitchen Ice Machine	7/23/2016 7:16	7/28/2016	43510	LEAD	<1 PPB	15 PPB
61-28A C-105 Student Store Sink Faucet	7/23/2016 7:18	7/28/2016	43511	LEAD	1 PPB	15 PPB
61-29A Main Office Sink Faucet	7/23/2016 7:20	7/28/2016	43512	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-30A C112J Kitchen Sink Faucet	7/23/2016 7:22	7/28/2016	43513	LEAD	<1 PPB	15 PPB
61-31A C112F Student Health Sink Faucet	7/23/2016 7:24	7/28/2016	43514	LEAD	<1 PPB	15 PPB
61-32A B-113 Sink Faucet	7/23/2016 7:26	7/28/2016	43515	LEAD	<1 PPB	15 PPB
61-33A B-112 Sink Faucet	7/23/2016 7:28	7/28/2016	43516	LEAD	1 PPB	15 PPB
61-34A B Hall Drinking Fountain (Left)	7/23/2016 7:30	7/28/2016	43517	LEAD	1 PPB	15 PPB
61-35A B Hall Drinking Fountain (Right)	7/23/2016 7:32	7/28/2016	43518	LEAD	<1 PPB	15 PPB
61-36A B-104 Sink Faucet	7/23/2016 7:34	7/28/2016	43519	LEAD	<1 PPB	15 PPB
61-37A B-105 Sink Faucet	7/23/2016 7:36	7/28/2016	43520	LEAD	<1 PPB	15 PPB
61-38A A116/117 Sink Faucet East Wall	7/23/2016 7:38	7/28/2016	43521	LEAD	<1 PPB	15 PPB
61-39A A116/117 Sink Faucet South Wall	7/23/2016 7:40	7/28/2016	43522	LEAD	1 PPB	15 PPB
61-40A A115 Sink Faucet North Wall	7/23/2016 7:42	7/28/2016	43523	LEAD	<1 PPB	15 PPB
61-41A A115 Sink Faucet East Wall	7/23/2016 7:44	7/28/2016	43524	LEAD	<1 PPB	15 PPB
61-42A A Hall Drinking Fountain (Left)	7/23/2016 7:46	7/28/2016	43525	LEAD	<1 PPB	15 PPB
61-43A A Hall Drinking Fountain (Right)	7/23/2016 7:48	7/28/2016	43526	LEAD	<1 PPB	15 PPB
61-44A A102 Drinking Fountain	7/23/2016 7:50	7/28/2016	43527	LEAD	<1 PPB	15 PPB
61-45A A102C Instrument Storage Sink Faucet	7/23/2016 7:52	7/28/2016	43528	LEAD	<1 PPB	15 PPB
61-46A A101 Drinking Fountain	7/23/2016 7:54	7/28/2016	43529	LEAD	<1 PPB	15 PPB
61-47A A100 Drinking Fountain	7/23/2016 7:56	7/28/2016	43530	LEAD	<1 PPB	15 PPB
61-48A 2nd Floor B Hall Drinking Fountain (Left)	7/23/2016 7:58	7/28/2016	43531	LEAD	<1 PPB	15 PPB
61-49A 2nd Floor B Hall Drinking Fountain (Right)	7/23/2016 8:00	7/28/2016	43532	LEAD	<1 PPB	15 PPB
61-50A B-202 Sink Faucet	7/23/2016 8:02	7/28/2016	43533	LEAD	<1 PPB	15 PPB
61-51A B-202 Sink Faucet	7/23/2016 8:04	7/28/2016	43534	LEAD	<1 PPB	15 PPB
61-52A B-203 Sink Faucet (Right)	7/23/2016 8:06	7/28/2016	43535	LEAD	<1 PPB	15 PPB
61-53A B-203 Sink Faucet (Left)	7/23/2016 8:08	7/28/2016	43536	LEAD	<1 PPB	15 PPB
61-54A B-209 Sink Faucet	7/23/2016 8:10	7/28/2016	43537	LEAD	<1 PPB	15 PPB
61-55A Library Hall Drinking Fountain (Left)	7/23/2016 8:12	7/28/2016	43538	LEAD	<1 PPB	15 PPB
61-56A Library Hall Drinking Fountain (Right)	7/23/2016 8:14	7/28/2016	43539	LEAD	<1 PPB	15 PPB
61-57A Library Workroom C202 Sink Faucet	7/23/2016 8:16	7/28/2016	43540	LEAD	<1 PPB	15 PPB
61-58A D-203 Sink Faucet	7/23/2016 8:18	7/28/2016	43541	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-59A D-227 Sink Faucet (Left)	7/23/2016 8:20	7/28/2016	43542	LEAD	2 PPB	15 PPB
61-60A D-227 Sink Faucet (Right)	7/23/2016 8:22	7/28/2016	43543	LEAD	2 PPB	15 PPB
61-61A D-226 Sink Faucet	7/23/2016 8:24	7/28/2016	43544	LEAD	<1 PPB	15 PPB
61-62A D-225 Sink Faucet	7/23/2016 8:26	7/28/2016	43545	LEAD	<1 PPB	15 PPB
61-64A D Wing Drinking Fountain (Left)	7/23/2016 8:28	7/28/2016	43546	LEAD	<1 PPB	15 PPB
61-65A D Wing Drinking Fountain (Right)	7/23/2016 8:30	7/28/2016	43547	LEAD	<1 PPB	15 PPB
61-66A Upper Gymnasium Drinking Fountain (Left)	7/23/2016 8:32	7/28/2016	43548	LEAD	<1 PPB	15 PPB
61-67A Upper Gymnasium Drinking Fountain (Right)	7/23/2016 8:34	7/28/2016	43549	LEAD	<1 PPB	15 PPB
61-68A 2nd Floor Gymnasium Snack Bar Sink Faucet	7/23/2016 8:36	7/28/2016	43550	LEAD	1 PPB	15 PPB
61-69A Gymnasium Hall Drinking Fountain 2nd Floor	7/23/2016 8:38	7/28/2016	43551	LEAD	<1 PPB	15 PPB
61-70A 1st Floor Gymnasium Hall Drinking Fountain (Left)	7/23/2016 6:24	7/28/2016	43552	LEAD	<1 PPB	15 PPB
61-71A 1st Floor Gymnasium Hall Drinking Fountain (Right)	7/23/2016 6:26	7/28/2016	43553	LEAD	<1 PPB	15 PPB
61-72A Outside Snack Shack Drinking Fountain (Left)	7/23/2016 8:43	7/28/2016	43554	LEAD	2 PPB	15 PPB
61-73A Outside Snack Shack Drinking Fountain (Right)	7/23/2016 8:45	7/28/2016	43555	LEAD	2 PPB	15 PPB
61-74A Outside Snack Shack Inside	7/23/2016 8:47	7/28/2016	43556	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-63A D-224 Sink Faucet	9/29/2016 4:54	10/3/2016	59447	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
061-75A 2nd Floor Gym Hall Bottle Filler w/76	1/6/2017 7:15	1/9/2017	794	LEAD	<1 PPB	15 PPB
061-76A 2nd Floor Gym Hall Drinking Fountain w/75	1/6/2017 7:15	1/9/2017	795	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
061-77A 2nd Floor B Hall Bottle Filler w/78	4/28/2017 6:32	5/2/2017	22384	LEAD	<1 PPB	15 PPB
061-78A 2nd Floor B Hall Bottle Filler w/78	4/28/2017 6:33	5/2/2017	22385	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-79A E115 Training Room ON Sink Cab	6/9/2017 7:06:00AM	6/13/2017	30980	LEAD	<1 PPB	15 PPB
61-80A E115 Training Room Left Whirlpool Fill	6/9/2017 7:08:00AM	6/13/2017	30981	LEAD	20 PPB	15 PPB
61-81A E115 Training Room Hose on Left Whirlpool	6/9/2017 7:010:00AM	6/13/2017	30982	LEAD	5 PPB	15 PPB
61-82A E115 Training Room Right Whirlpool	6/9/2017 7:12:00AM	6/13/2017	30983	LEAD	22 PPB	15 PPB
61-83A E115 Training Room Hose on Right Whirlpool	6/9/2017 7:14:00AM	6/13/2017	30984	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level