

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Whiteaker Middle School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results		Action Level
062-01A	Kitchen Food Prep Sink Faucet 1	7/19/16 7:08	7/28/2016	1607906-01A	COPPER	0.0	PPM	1.3 PPM
062-02A	Kitchen Food Prep Sink Faucet 2	7/19/16 7:11	7/28/2016	1607906-02A	COPPER	0.1	PPM	1.3 PPM
062-03A	Kitchen Food Prep Sink Faucet 3	7/19/16 7:14	7/28/2016	1607906-03A	COPPER	0.0	PPM	1.3 PPM
062-04A	Kitchen Food Prep Sink Faucet 4	7/19/16 7:16	7/28/2016	1607906-04A	COPPER	0.1	PPM	1.3 PPM
062-05A	Staff Lunch Room Sink Faucet	7/19/16 7:19	7/28/2016	1607906-05A	COPPER	0.2	PPM	1.3 PPM
062-06A	Cafeteria Drinking Fountain	7/19/16 7:23	7/28/2016	1607906-06A	COPPER	0.1	PPM	1.3 PPM
062-07A	Hallway Drinking Fountain 1	7/19/16 7:27	7/28/2016	1607906-07A	COPPER	0.1	PPM	1.3 PPM
062-08A	Gymnasium Drinking Fountain 1	7/19/16 7:54	7/28/2016	1607906-08A	COPPER	0.3	PPM	1.3 PPM
062-09A	Gymnasium Drinking Fountain 2	7/19/16 7:56	7/28/2016	1607906-09A	COPPER	0.3	PPM	1.3 PPM
062-10A	Upstairs Gymnasium Drinking Fountain	7/19/16 8:03	7/28/2016	1607906-10A	COPPER	0.2	PPM	1.3 PPM
062-11A	Girls Locker Room Drinking Fountain	7/19/16 8:06	7/28/2016	1607906-11A	COPPER	0.2	PPM	1.3 PPM
062-12A	Boys Locker Room Drinking Fountain	7/19/16 8:00	7/28/2016	1607906-12A	COPPER	0.3	PPM	1.3 PPM
062-13A	Hallway Drinking Fountain 2	7/19/16 8:50	7/28/2016	1607906-13A	COPPER	0.1	PPM	1.3 PPM
062-14A	Music Storage Room Drinking Fountain	7/19/16 8:59	7/28/2016	1607906-14A	COPPER	0.0	PPM	1.3 PPM
062-15A	Music Storage Room Sink Faucet	7/19/16 9:01	7/28/2016	1607906-15A	COPPER	0.1	PPM	1.3 PPM
062-16A	Hallway Drinking Fountain 3	7/19/16 8:53	7/28/2016	1607906-16A	COPPER	0.2	PPM	1.3 PPM
062-17A	Hallway Drinking Fountain 4	7/19/16 8:55	7/28/2016	1607906-17A	COPPER	0.3	PPM	1.3 PPM
062-18A	Hallway Drinking Fountain 5	7/19/16 8:47	7/28/2016	1607906-18A	COPPER	0.2	PPM	1.3 PPM
062-19A	Hallway Drinking Fountain 6	7/19/16 8:44	7/28/2016	1607906-19A	COPPER	0.1	PPM	1.3 PPM
062-20A	Home Economics 116 Sink Faucet 1	7/19/16 8:15	7/28/2016	1607906-20A	COPPER	0.1	PPM	1.3 PPM
062-21A	Home Economics 116 Sink Faucet 2	7/19/16 8:17	7/26/2016	1607906-21A	COPPER	0.1	PPM	1.3 PPM
062-22A	Home Economics 116 Sink Faucet 3	7/19/16 8:19	7/26/2016	1607906-22A	COPPER	0.1	PPM	1.3 PPM
062-23A	Home Economics 116 Sink Faucet 4	7/19/16 8:21	7/26/2016	1607906-23A	COPPER	0.0	PPM	1.3 PPM
062-24A	Home Economics 116 Sink Faucet 5	7/19/16 8:23	7/26/2016	1607906-24A	COPPER	0.1	PPM	1.3 PPM
062-25A	Home Economics 116 Sink Faucet 6	7/19/16 8:25	7/26/2016	1607906-25A	COPPER	0.1	PPM	1.3 PPM
062-26A	Home Economics 116 Sink Faucet 7	7/19/16 8:27	7/26/2016	1607906-26A	COPPER	0.0	PPM	1.3 PPM
062-27A	Home Economics 116 Sink Faucet 8	7/19/16 8:29	7/26/2016	1607906-27A	COPPER	0.1	PPM	1.3 PPM
062-28A	Home Economics 115 Sink Faucet	7/19/16 8:35	7/26/2016	1607906-28A	COPPER	0.0	PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Whiteaker Middle School

062-29A	Room 110 Sink Faucet	7/19/16 8:38	7/26/2016	1607906-29A	COPPER	0.1	PPM	1.3 PPM
062-31A	Hallway Drinking Fountain 7	7/19/16 7:45	7/26/2016	1607906-30A	COPPER	0.4	PPM	1.3 PPM
062-32A	Shop 107 Drinking Fountain	7/19/16 7:41	7/26/2016	1607906-31A	COPPER	0.1	PPM	1.3 PPM
062-33A	Room 109 Sink Faucet	7/19/16 9:25	7/26/2016	1607906-32A	COPPER	0.1	PPM	1.3 PPM
062-34A	Room 109 Drinking Fountain	7/19/16 9:27	7/26/2016	1607906-33A	COPPER	0.2	PPM	1.3 PPM
062-35A	Room 106 Sink Faucet	7/19/16 7:36	7/26/2016	1607906-34A	COPPER	0.0	PPM	1.3 PPM
062-36A	Room 106 Drinking Fountain	7/19/16 7:38	7/26/2016	1607906-35A	COPPER	0.0	PPM	1.3 PPM
062-37A	Hallway Drinking Fountain 8	7/19/16 7:32	7/26/2016	1607906-36A	COPPER	0.1	PPM	1.3 PPM
062-38A	Workroom 160A Sink Faucet	7/19/16 9:33	7/26/2016	1607906-37A	COPPER	0.2	PPM	1.3 PPM
062-39A	Workroom 160B Drinking Fountain	7/19/16 9:35	7/26/2016	1607906-38A	COPPER	0.2	PPM	1.3 PPM
062-40A	Health 160B Sink Faucet	7/19/16 9:38	7/26/2016	1607906-39A	COPPER	0.2	PPM	1.3 PPM
062-41A	Health 160B Drinking Fountain	7/19/16 9:40	7/26/2016	1607906-40A	COPPER	0.2	PPM	1.3 PPM
062-43A	Hallway Drinking Fountain 9	7/19/16 9:44	7/25/2016	1607906-41A	COPPER	0.1	PPM	1.3 PPM
062-44A	Hallway Drinking Fountain 10	7/19/16 9:46	7/25/2016	1607906-42A	COPPER	0.1	PPM	1.3 PPM
062-45A	Hallway Drinking Fountain	7/19/16 9:20	7/25/2016	1607906-43A	COPPER	0.1	PPM	1.3 PPM
062-46A	Room 133 Sink Faucet	7/19/16 9:55	7/25/2016	1607906-44A	COPPER	0.0	PPM	1.3 PPM
062-47A	Room 133 Drinking Fountain	7/19/16 9:57	7/25/2016	1607906-45A	COPPER	0.1	PPM	1.3 PPM
062-48A	Room 132 Sink Faucet	7/19/16 9:15	7/25/2016	1607906-46A	COPPER	0.0	PPM	1.3 PPM
062-49A	Room 132 Drinking Fountain	7/19/16 9:17	7/25/2016	1607906-47A	COPPER	0.0	PPM	1.3 PPM
062-52A	Kitchen Ice-O-Matic	7/19/16 7:49	7/25/2016	1607906-48A	COPPER	<0.005	PPM	1.3 PPM
062-53A	Room 131 Drinking Fountain	7/19/16 10:02	7/25/2016	1607906-49A	COPPER	0.3	PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level