

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Whiteaker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
062-01A Kitchen Food Prep Sink Faucet 1	7/19/16 7:08	7/28/2016	1607906-01A	LEAD	<1.0 PPB	15 PPB
062-02A Kitchen Food Prep Sink Faucet 2	7/19/16 7:11	7/28/2016	1607906-02A	LEAD	1 PPB	15 PPB
062-03A Kitchen Food Prep Sink Faucet 3	7/19/16 7:14	7/28/2016	1607906-03A	LEAD	2 PPB	15 PPB
062-04A Kitchen Food Prep Sink Faucet 4	7/19/16 7:16	7/28/2016	1607906-04A	LEAD	3 PPB	15 PPB
062-05A Staff Lunch Room Sink Faucet	7/19/16 7:19	7/28/2016	1607906-05A	LEAD	<1.0 PPB	15 PPB
062-06A Cafeteria Drinking Fountain	7/19/16 7:23	7/28/2016	1607906-06A	LEAD	<1.0 PPB	15 PPB
062-07A Hallway Drinking Fountain 1	7/19/16 7:27	7/28/2016	1607906-07A	LEAD	<1.0 PPB	15 PPB
062-08A Gymnasium Drinking Fountain 1	7/19/16 7:54	7/28/2016	1607906-08A	LEAD	<1.0 PPB	15 PPB
062-09A Gymnasium Drinking Fountain 2	7/19/16 7:56	7/28/2016	1607906-09A	LEAD	<1.0 PPB	15 PPB
062-10A Upstairs Gymnasium Drinking Fountain	7/19/16 8:03	7/28/2016	1607906-10A	LEAD	<1.0 PPB	15 PPB
062-11A Girls Locker Room Drinking Fountain	7/19/16 8:06	7/28/2016	1607906-11A	LEAD	4 PPB	15 PPB
062-12A Boys Locker Room Drinking Fountain	7/19/16 8:00	7/28/2016	1607906-12A	LEAD	<1.0 PPB	15 PPB
062-13A Hallway Drinking Fountain 2	7/19/16 8:50	7/28/2016	1607906-13A	LEAD	<1.0 PPB	15 PPB
062-14A Music Storage Room Drinking Fountain	7/19/16 8:59	7/28/2016	1607906-14A	LEAD	1 PPB	15 PPB
062-15A Music Storage Room Sink Faucet	7/19/16 9:01	7/28/2016	1607906-15A	LEAD	<1.0 PPB	15 PPB
062-16A Hallway Drinking Fountain 3	7/19/16 8:53	7/28/2016	1607906-16A	LEAD	1 PPB	15 PPB
062-17A Hallway Drinking Fountain 4	7/19/16 8:55	7/28/2016	1607906-17A	LEAD	<1.0 PPB	15 PPB
062-18A Hallway Drinking Fountain 5	7/19/16 8:47	7/28/2016	1607906-18A	LEAD	<1.0 PPB	15 PPB
062-19A Hallway Drinking Fountain 6	7/19/16 8:44	7/28/2016	1607906-19A	LEAD	<1.0 PPB	15 PPB
062-20A Home Economics 116 Sink Faucet 1	7/19/16 8:15	7/28/2016	1607906-20A	LEAD	<1.0 PPB	15 PPB
062-21A Home Economics 116 Sink Faucet 2	7/19/16 8:17	7/26/2016	1607906-21A	LEAD	3 PPB	15 PPB
062-22A Home Economics 116 Sink Faucet 3	7/19/16 8:19	7/26/2016	1607906-22A	LEAD	<1.0 PPB	15 PPB
062-23A Home Economics 116 Sink Faucet 4	7/19/16 8:21	7/26/2016	1607906-23A	LEAD	<1.0 PPB	15 PPB
062-24A Home Economics 116 Sink Faucet 5	7/19/16 8:23	7/26/2016	1607906-24A	LEAD	<1.0 PPB	15 PPB
062-25A Home Economics 116 Sink Faucet 6	7/19/16 8:25	7/26/2016	1607906-25A	LEAD	<1.0 PPB	15 PPB
062-26A Home Economics 116 Sink Faucet 7	7/19/16 8:27	7/26/2016	1607906-26A	LEAD	1 PPB	15 PPB
062-27A Home Economics 116 Sink Faucet 8	7/19/16 8:29	7/26/2016	1607906-27A	LEAD	<1.0 PPB	15 PPB
062-28A Home Economics 115 Sink Faucet	7/19/16 8:35	7/26/2016	1607906-28A	LEAD	3 PPB	15 PPB
062-29A Room 110 Sink Faucet	7/19/16 8:38	7/26/2016	1607906-29A	LEAD	2 PPB	15 PPB
062-31A Hallway Drinking Fountain 7	7/19/16 7:45	7/26/2016	1607906-30A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Whiteaker Middle School

062-32A	Shop 107 Drinking Fountain	7/19/16 7:41	7/26/2016	1607906-31A	LEAD	2	PPB	15	PPB
062-33A	Room 109 Sink Faucet	7/19/16 9:25	7/26/2016	1607906-32A	LEAD	<1.0	PPB	15	PPB
062-34A	Room 109 Drinking Fountain	7/19/16 9:27	7/26/2016	1607906-33A	LEAD	<1.0	PPB	15	PPB
062-35A	Room 106 Sink Faucet	7/19/16 7:36	7/26/2016	1607906-34A	LEAD	<1.0	PPB	15	PPB
062-36A	Room 106 Drinking Fountain	7/19/16 7:38	7/26/2016	1607906-35A	LEAD	2	PPB	15	PPB
062-37A	Hallway Drinking Fountain 8	7/19/16 7:32	7/26/2016	1607906-36A	LEAD	<1.0	PPB	15	PPB
062-38A	Workroom 160A Sink Faucet	7/19/16 9:33	7/26/2016	1607906-37A	LEAD	<1.0	PPB	15	PPB
062-39A	Workroom 160B Drinking Fountain	7/19/16 9:35	7/26/2016	1607906-38A	LEAD	<1.0	PPB	15	PPB
062-40A	Health 160B Sink Faucet	7/19/16 9:38	7/26/2016	1607906-39A	LEAD	<1.0	PPB	15	PPB
062-41A	Health 160B Drinking Fountain	7/19/16 9:40	7/26/2016	1607906-40A	LEAD	<1.0	PPB	15	PPB
062-43A	Hallway Drinking Fountain 9	7/19/16 9:44	7/25/2016	1607906-41A	LEAD	<1.0	PPB	15	PPB
062-44A	Hallway Drinking Fountain 10	7/19/16 9:46	7/25/2016	1607906-42A	LEAD	<1.0	PPB	15	PPB
062-45A	Hallway Drinking Fountain	7/19/16 9:20	7/25/2016	1607906-43A	LEAD	<1.0	PPB	15	PPB
062-46A	Room 133 Sink Faucet	7/19/16 9:55	7/25/2016	1607906-44A	LEAD	5	PPB	15	PPB
062-47A	Room 133 Drinking Fountain	7/19/16 9:57	7/25/2016	1607906-45A	LEAD	<1.0	PPB	15	PPB
062-48A	Room 132 Sink Faucet	7/19/16 9:15	7/25/2016	1607906-46A	LEAD	3	PPB	15	PPB
062-49A	Room 132 Drinking Fountain	7/19/16 9:17	7/25/2016	1607906-47A	LEAD	<1.0	PPB	15	PPB
062-52A	Kitchen Ice-O-Matic	7/19/16 7:49	7/25/2016	1607906-48A	LEAD	<1.0	PPB	15	PPB
062-53A	Room 131 Drinking Fountain	7/19/16 10:02	7/25/2016	1607906-49A	LEAD	3	PPB	15	PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level