

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Results  
Wright Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result		Action Level
041-01A	Auditorium/Cafeteria Drinking Fountain	7/14/16 7:00	7/23/2016	1607813-01A	LEAD	9	PPB	15 PPB
041-02A	Room 12 Sink Faucet	7/14/16 7:20	7/23/2016	1607813-02A	LEAD	3	PPB	15 PPB
041-03A	Room 12 Drinking Fountain	7/14/16 7:22	7/23/2016	1607813-03A	LEAD	1	PPB	15 PPB
041-04A	Room 13 Sink Faucet	7/14/16 7:28	7/23/2016	1607813-04A	LEAD	19	PPB	15 PPB
041-05A	Room 13 Drinking Fountain	7/14/16 7:30	7/23/2016	1607813-05A	LEAD	1	PPB	15 PPB
041-06A	Room 14 Sink Faucet	7/14/16 7:47	7/23/2016	1607813-06A	LEAD	2	PPB	15 PPB
041-07A	Room 14 Drinking Fountain	7/14/16 7:49	7/23/2016	1607813-07A	LEAD	2	PPB	15 PPB
041-08A	Room 15 Sink Faucet	7/14/16 7:40	7/23/2016	1607813-08A	LEAD	<1.0	PPB	15 PPB
041-09A	Room 15 Drinking Fountain	7/14/16 7:42	7/23/2016	1607813-09A	LEAD	2	PPB	15 PPB
041-10A	Hall Corridor D Drinking Fountain 1	7/14/16 7:53	7/23/2016	1607813-10A	LEAD	10	PPB	15 PPB
041-11A	Room 16 Sink Faucet	7/14/16 8:00	7/23/2016	1607813-11A	LEAD	6	PPB	15 PPB
041-12A	Room 16 Drinking Fountain	7/14/16 8:02	7/23/2016	1607813-12A	LEAD	2	PPB	15 PPB
041-13A	Room 19 Sink Faucet	7/14/16 8:05	7/23/2016	1607813-13A	LEAD	11	PPB	15 PPB
041-14A	Room 19 Drinking Fountain	7/14/16 8:07	7/23/2016	1607813-14A	LEAD	2	PPB	15 PPB
041-15A	Hall Corridor D Drinking Fountain 2	7/14/16 8:10	7/23/2016	1607813-15A	LEAD	3	PPB	15 PPB
041-16A	Hall Corridor D Drinking Fountain 3	7/14/16 8:12	7/23/2016	1607813-16A	LEAD	3	PPB	15 PPB
041-17A	Room 21 Sink Faucet	7/14/16 8:15	7/23/2016	1607813-17A	LEAD	5	PPB	15 PPB
041-18A	Room 21 Drinking Fountain	7/15/16 8:17	7/23/2016	1607813-18A	LEAD	<1.0	PPB	15 PPB
041-19A	Room 23 Sink Faucet	7/14/16 8:20	7/23/2016	1607813-19A	LEAD	4	PPB	15 PPB
041-20A	Room 23 Drinking Fountain	7/14/16 8:22	7/23/2016	1607813-20A	LEAD	<1.0	PPB	15 PPB
041-21A	Room 18 Sink Faucet	7/14/16 8:25	7/23/2016	1607813-21A	LEAD	2	PPB	15 PPB
041-22A	Room 18 Drinking Fountain	7/14/16 8:27	7/23/2016	1607813-22A	LEAD	<1.0	PPB	15 PPB
041-23A	Room 22 Sink Faucet	7/14/16 8:30	7/23/2016	1607813-23A	LEAD	5	PPB	15 PPB
041-24A	Room 22 Drinking Fountain	7/14/16 8:32	7/23/2016	1607813-24A	LEAD	<1.0	PPB	15 PPB
041-25A	Room 20 Sink Faucet	7/14/16 8:35	7/23/2016	1607813-25A	LEAD	4	PPB	15 PPB
041-26A	Room 20 Drinking Fountain	7/14/16 8:37	7/23/2016	1607813-26A	LEAD	1	PPB	15 PPB
041-27A	Staff Lounge Sink Faucet 1	7/14/16 7:12	7/23/2016	1607813-27A	LEAD	9	PPB	15 PPB
041-28A	Staff Lounge Sink Faucet 2	7/14/16 7:10	7/23/2016	1607813-28A	LEAD	7	PPB	15 PPB
041-29A	Nurse Office Sink Faucet	7/14/16 8:45	7/23/2016	1607813-29A	LEAD	6	PPB	15 PPB
041-30A	Nurse Office Drinking Fountain	7/14/16 8:47	7/23/2016	1607813-30A	LEAD	6	PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Results  
Wright Elementary School

041-31A	Hallway Corridor B Drinking Fountain	7/14/16 8:50	7/23/2016	1607813-31A	LEAD	4	PPB	15 PPB
041-32A	Room 9 Sink Faucet	7/14/16 8:54	7/23/2016	1607813-32A	LEAD	59	PPB	15 PPB
041-33A	Room 9 Drinking Fountain	7/14/16 8:56	7/23/2016	1607813-33A	LEAD	6	PPB	15 PPB
041-34A	Room 8 Sink Faucet	7/14/16 8:59	7/23/2016	1607813-34A	LEAD	12	PPB	15 PPB
041-35A	Room 8 Drinking Fountain	7/14/16 9:01	7/23/2016	1607813-35A	LEAD	1	PPB	15 PPB
041-36A	Room 6 Sink Faucet	7/14/16 9:05	7/23/2016	1607813-36A	LEAD	18	PPB	15 PPB
041-37A	Room 6 Drinking Fountain	7/14/16 9:07	7/23/2016	1607813-37A	LEAD	<1.0	PPB	15 PPB
041-38A	Room 7 Sink Faucet	7/14/16 9:11	7/23/2016	1607813-38A	LEAD	46	PPB	15 PPB
041-39A	Room 7 Drinking Fountain	7/14/16 9:13	7/23/2016	1607813-39A	LEAD	4	PPB	15 PPB
041-40A	Room 5 Sink Faucet	7/14/16 9:18	7/23/2016	1607813-40A	LEAD	4	PPB	15 PPB
041-41A	Room 5 Drinking Fountain	7/14/16 9:20	7/23/2016	1607813-41A	LEAD	5	PPB	15 PPB
041-42A	Room 4 Sink Faucet	7/14/16 9:25	7/23/2016	1607813-42A	LEAD	3	PPB	15 PPB
041-43A	Room 4 Drinking Fountain	7/14/16 9:27	7/23/2016	1607813-43A	LEAD	<1.0	PPB	15 PPB
041-44A	Room 3 Sink Faucet	7/14/16 9:37	7/23/2016	1607813-44A	LEAD	5	PPB	15 PPB
041-45A	Room 3 Drinking Fountain	7/14/16 9:39	7/23/2016	1607813-45A	LEAD	3	PPB	15 PPB
041-46A	Room 1 Sink Faucet	7/14/16 9:43	7/23/2016	1607813-46A	LEAD	8	PPB	15 PPB
041-47A	Room 1 Drinking Fountain	7/14/16 9:45	7/23/2016	1607813-47A	LEAD	26	PPB	15 PPB
041-48A	Room 2 Sink Faucet	7/14/16 9:30	7/23/2016	1607813-48A	LEAD	5	PPB	15 PPB
041-49A	Room 2 Drinking Fountain	7/14/16 9:32	7/23/2016	1607813-49A	LEAD	4	PPB	15 PPB
041-50A	Hall Corridor A Drinking Fountain 4	7/14/16 9:49	7/23/2016	1607813-50A	LEAD	13	PPB	15 PPB
041-51A	Music Room Sink Faucet	7/14/16 9:53	7/23/2016	1607813-51A	LEAD	4	PPB	15 PPB
041-52A	Music Room Drinking Fountain	7/14/16 9:55	7/23/2016	1607813-52A	LEAD	14	PPB	15 PPB
041-53A	Gymnasium Drinking Fountain	7/14/16 9:59	7/23/2016	1607813-53A	LEAD	3	PPB	15 PPB
041-54A	Room 17 Sink Faucet	7/14/16 7:40	7/23/2016	1607813-54A	LEAD	9	PPB	15 PPB
041-55A	Room 17 Drinking Fountain	7/14/16 7:42	7/23/2016	1607813-55A	LEAD	2	PPB	15 PPB
041-57A	Kitchen Food Prep #1 Sink Faucet	7/14/16 7:02	7/23/2016	1607813-56A	LEAD	47	PPB	15 PPB
041-58A	Kitchen Food Prep #2 Sink Faucet	7/14/16 7:04	7/23/2016	1607813-57A	LEAD	6	PPB	15 PPB
041-59A	Kitchen Food Prep #3 Sink Faucet	7/14/16 7:06	7/25/2016	1607813-58A	LEAD	2	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-04B Room 13 Sink Faucet	7/14/16 7:29	8/7/2016	1607814-04A	LEAD	<1.0 PPB	15 PPB
041-32B Room 9 Sink Faucet	7/14/16 8:55	8/7/2016	1607814-32A	LEAD	3 PPB	15 PPB
041-36B Room 6 Sink Faucet	7/14/16 9:06	8/7/2016	1607814-36A	LEAD	<1.0 PPB	15 PPB
041-38B Room 7 Sink Faucet	7/14/16 9:12	8/7/2016	1607814-38A	LEAD	3 PPB	15 PPB
041-47B Room 1 Drinking Fountain	7/14/16 9:46	8/7/2016	1607814-47A	LEAD	12 PPB	15 PPB
041-57B Kitchen Food Prep #1 Sink Faucet	7/14/16 7:03	8/7/2016	1607814-56A	LEAD	<1.0 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (C) Sample Data  
 Wright Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result		Action Level
041-04C	Room 13 Sink Faucet	9/29/2016 6:24	10/3/2016	59456	LEAD	9	PPB	15 PPB
041-32C	Room 9 Sink Faucet	9/29/2016 6:27	10/3/2016	59457	LEAD	35	PPB	15 PPB
041-36C	Room 6 Sink Faucet	9/29/2016 6:33	10/3/2016	59458	LEAD	8	PPB	15 PPB
041-38C	Room 7 Sink Faucet	9/29/2016 6:38	10/3/2016	59459	LEAD	26	PPB	15 PPB
041-47C	Room 1 Drinking Fountain	9/29/2016 6:44	10/3/2016	59460	LEAD	16	PPB	15 PPB
041-57C	Kitchen Food Prep #1 Sink Faucet	9/29/2016 6:49	10/3/2016	59461	LEAD	3	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (E) Sample Data  
Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-32E Room 9 Sink Faucet	3/16/2017 6:08	3/17/2017	13881	LEAD	6 PPB	15 PPB
041-38E Room 7 Sink Faucet	3/16/2017 6:13	3/17/2017	13882	LEAD	7 PPB	15 PPB
041-47E Room 1 Drinking Fountain	3/16/2017 6:18	3/17/2017	13883	LEAD	11 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (D) Sample Data  
Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-32D Room 9 Sink Faucet	9/29/2016 6:28	10/18/2016	63612	LEAD	12 PPB	15 PPB
041-38D Room 7 Sink Faucet	9/29/2016 6:39	10/18/2016	63613	LEAD	5 PPB	15 PPB
041-47D Room 1 Drinking Fountain	9/29/2016 6:45	10/18/2016	63614	LEAD	14 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level