

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-01A Gymnasium- Drinking Fountain (Left)	7/22/2016 9:15	8/12/2016	44906	COPPER	0.1 PPM	1.3 PPM
64-02A Gymnasium Drinking Fountain (Right)	7/22/2016 9:17	8/12/2016	44907	COPPER	0.1 PPM	1.3 PPM
64-03A Kitchen Sink Faucet	7/22/2016 9:19	8/12/2016	44908	COPPER	0.1 PPM	1.3 PPM
64-04A Cafeteria Closet Sink Faucet	7/22/2016 9:21	8/12/2016	44909	COPPER	0.2 PPM	1.3 PPM
64-05A Cafeteria Restroom Drinking Fountain (Left)	7/22/2016 9:24	8/16/2016	44910	COPPER	0.1 PPM	1.3 PPM
64-06A Cafeteria Restroom Drinking Fountain (Right)	7/22/2016 9:26	8/16/2016	44911	COPPER	0.0 PPM	1.3 PPM
64-07A Music Room Sink Faucet	7/22/2016 9:29	8/16/2016	44912	COPPER	0.4 PPM	1.3 PPM
64-08A Music Room Drinking Fountain	7/22/2016 9:31	8/16/2016	44913	COPPER	0.2 PPM	1.3 PPM
64-09A Nurse's Room Sink Faucet	7/22/2016 9:34	8/16/2016	44914	COPPER	0.2 PPM	1.3 PPM
64-10A Nurse's Room Drinking Fountain	7/22/2016 9:36	8/16/2016	44915	COPPER	0.1 PPM	1.3 PPM
64-11A Staff Lounge Sink Faucet	7/22/2016 9:38	8/16/2016	44916	COPPER	0.1 PPM	1.3 PPM
64-12A B-Pod Hall Sink Faucet	7/22/2016 9:40	8/16/2016	44917	COPPER	0.2 PPM	1.3 PPM
64-13A B-Pod Hall Drinking Fountain	7/22/2016 9:42	8/16/2016	44918	COPPER	0.1 PPM	1.3 PPM
64-14A B-1 Sink Faucet	7/22/2016 9:45	8/16/2016	44919	COPPER	0.2 PPM	1.3 PPM
64-15A B-1 Drinking Fountain	7/22/2016 9:47	8/16/2016	44920	COPPER	0.1 PPM	1.3 PPM
64-16A B-2 Sink Faucet	7/22/2016 9:49	8/16/2016	44921	COPPER	0.2 PPM	1.3 PPM
64-17A B-2 Drinking Fountain	7/22/2016 9:51	8/16/2016	44922	COPPER	0.2 PPM	1.3 PPM
64-18A B-3 Sink Faucet	7/22/2016 9:53	8/16/2016	44923	COPPER	0.2 PPM	1.3 PPM
64-19A B-3 Drinking Fountain	7/22/2016 9:55	8/16/2016	44924	COPPER	0.1 PPM	1.3 PPM
64-20A B-4 Sink Faucet	7/22/2016 9:57	8/16/2016	44925	COPPER	0.2 PPM	1.3 PPM
64-21A B-4 Drinking fountain	7/22/2016 9:56	8/16/2016	44926	COPPER	0.3 PPM	1.3 PPM
64-22A B-5 Sink Faucet	7/22/2016 10:01	8/16/2016	44927	COPPER	0.2 PPM	1.3 PPM
64-23A B-5 Drinking Fountain	7/22/2016 10:03	8/16/2016	44928	COPPER	0.2 PPM	1.3 PPM
64-24A B-6 Sink Faucet	7/22/2016 10:05	8/16/2016	44929	COPPER	0.2 PPM	1.3 PPM
64-25A B-6 Drinking Fountain	7/22/2016 10:07	8/12/2016	44930	COPPER	0.2 PPM	1.3 PPM
64-26A Media Center Sink Faucet	7/22/2016 10:09	8/12/2016	44931	COPPER	0.2 PPM	1.3 PPM
64-27A Media Center Drinking Fountain	7/22/2016 10:11	8/12/2016	44932	COPPER	0.2 PPM	1.3 PPM
64-28A Media Center Hall Restroom Drinking Fountain	7/22/2016 10:13	8/12/2016	44933	COPPER	0.2 PPM	1.3 PPM
64-29A C-Pod Hall Sink Faucet	7/22/2016 10:16	8/12/2016	44934	COPPER	0.2 PPM	1.3 PPM
64-30A C-Pod Hall Drinking Fountain	7/22/2016 10:18	8/12/2016	44935	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-31A C-1 Sink Faucet	7/22/2016 10:20	8/12/2016	44936	COPPER	0.2 PPM	1.3 PPM
64-32A C-1 Drinking Fountain	7/22/2016 10:22	8/16/2016	44937	COPPER	0.2 PPM	1.3 PPM
64-33A C-2 Sink Faucet	7/22/2016 10:24	8/12/2016	44938	COPPER	0.3 PPM	1.3 PPM
64-34A C-2 Drinking Fountain	7/22/2016 10:26	8/12/2016	44939	COPPER	0.1 PPM	1.3 PPM
64-35A C-3 Sink Faucet	7/22/2016 10:28	8/16/2016	44940	COPPER	0.2 PPM	1.3 PPM
64-36A C-3 Drinking Fountain	7/22/2016 10:30	8/16/2016	44941	COPPER	0.2 PPM	1.3 PPM
64-37A C-4 Sink Faucet	7/22/2016 10:32	8/16/2016	44942	COPPER	0.2 PPM	1.3 PPM
64-38A c-4 Drinking Fountain	7/22/2016 10:34	8/16/2016	44943	COPPER	0.2 PPM	1.3 PPM
64-39A C-5 Sink Faucet	7/22/2016 10:36	8/16/2016	44944	COPPER	0.2 PPM	1.3 PPM
64-40A C-5 Drinking Fountain	7/22/2016 10:38	8/16/2016	44945	COPPER	0.2 PPM	1.3 PPM
64-41A C-6 Sink Faucet	7/22/2016 10:40	8/16/2016	44946	COPPER	0.2 PPM	1.3 PPM
64-42A C-6 Drinking Fountain	7/22/2016 10:42	8/16/2016	44947	COPPER	0.1 PPM	1.3 PPM
64-43A A-Pod Hall Sink Faucet	7/22/2016 10:45	8/16/2016	44948	COPPER	0.2 PPM	1.3 PPM
64-44A A-Pod Hall Drinking Fountain	7/22/2016 10:47	8/16/2016	44949	COPPER	0.1 PPM	1.3 PPM
64-45A A-1 Sink Faucet	7/22/2016 10:49	8/16/2016	44950	COPPER	0.1 PPM	1.3 PPM
64-46A A-1 Drinking Fountain	7/22/2016 10:51	8/16/2016	44951	COPPER	0.1 PPM	1.3 PPM
64-47A A-2 Sink Faucet	7/22/2016 10:53	8/16/2016	44952	COPPER	0.1 PPM	1.3 PPM
64-48A A-2 Drinking Fountain	7/22/2016 10:55	8/16/2016	44953	COPPER	0.2 PPM	1.3 PPM
64-49A A-3 Sink Faucet	7/22/2016 10:57	8/16/2016	44954	COPPER	0.1 PPM	1.3 PPM
64-50A A-3 Drinking Fountain	7/22/2016 10:59	8/16/2016	44955	COPPER	0.1 PPM	1.3 PPM
64-51A A-4 Sink Faucet	7/22/2016 11:01	8/16/2016	44956	COPPER	0.1 PPM	1.3 PPM
64-52A A-4 Drinking Fountain	7/22/2016 11:03	8/16/2016	44957	COPPER	0.2 PPM	1.3 PPM
64-53A A-5 Sink Faucet	7/22/2016 11:05	8/16/2016	44958	COPPER	0.1 PPM	1.3 PPM
64-54A A-5 Drinking Fountain	7/22/2016 11:07	8/16/2016	44959	COPPER	0.1 PPM	1.3 PPM
64-55A A-6 Sink Faucet	7/22/2016 11:09	8/16/2016	44960	COPPER	0.2 PPM	1.3 PPM
64-56A A-6 Drinking Fountain	7/22/2016 11:11	8/16/2016	44961	COPPER	0.1 PPM	1.3 PPM
64-57A Portable 603 Sink Faucet	7/22/2016 11:15	8/16/2016	44962	COPPER	0.1 PPM	1.3 PPM
64-58A Portable 603 Drinking Fountain	7/22/2016 11:17	8/16/2016	44963	COPPER	0.1 PPM	1.3 PPM
64-59A Portable 604 Sink Faucet	7/22/2016 11:19	8/16/2016	44964	COPPER	0.1 PPM	1.3 PPM
64-60A Portable 604 Drinking Fountain	7/22/2016 11:21	8/16/2016	44965	COPPER	0.1 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-04C Cafeteria Closet Sink Faucet	10/28/2016 6:30	11/1/2016	65998	COPPER	0.3 PPM	1.3 PPM
64-12C B-Pod Hall Sink Faucet	10/28/2016 6:34	11/1/2016	65999	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level