

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-01A Gymnasium- Drinking Fountain (Left)	7/22/2016 9:15	8/12/2016	44906	LEAD	<1 PPB	15 PPB
64-02A Gymnasium Drinking Fountain (Right)	7/22/2016 9:17	8/12/2016	44907	LEAD	<1 PPB	15 PPB
64-03A Kitchen Sink Faucet	7/22/2016 9:19	8/12/2016	44908	LEAD	2 PPB	15 PPB
64-04A Cafeteria Closet Sink Faucet	7/22/2016 9:21	8/12/2016	44909	LEAD	23 PPB	15 PPB
64-05A Cafeteria Restroom Drinking Fountain (Left)	7/22/2016 9:24	8/16/2016	44910	LEAD	<1 PPB	15 PPB
64-06A Cafeteria Restroom Drinking Fountain (Right)	7/22/2016 9:26	8/16/2016	44911	LEAD	<1 PPB	15 PPB
64-07A Music Room Sink Faucet	7/22/2016 9:29	8/16/2016	44912	LEAD	10 PPB	15 PPB
64-08A Music Room Drinking Fountain	7/22/2016 9:31	8/16/2016	44913	LEAD	<1 PPB	15 PPB
64-09A Nurse's Room Sink Faucet	7/22/2016 9:34	8/16/2016	44914	LEAD	13 PPB	15 PPB
64-10A Nurse's Room Drinking Fountain	7/22/2016 9:36	8/16/2016	44915	LEAD	<1 PPB	15 PPB
64-11A Staff Lounge Sink Faucet	7/22/2016 9:38	8/16/2016	44916	LEAD	1 PPB	15 PPB
64-12A B-Pod Hall Sink Faucet	7/22/2016 9:40	8/16/2016	44917	LEAD	20 PPB	15 PPB
64-13A B-Pod Hall Drinking Fountain	7/22/2016 9:42	8/16/2016	44918	LEAD	<1 PPB	15 PPB
64-14A B-1 Sink Faucet	7/22/2016 9:45	8/16/2016	44919	LEAD	3 PPB	15 PPB
64-15A B-1 Drinking Fountain	7/22/2016 9:47	8/16/2016	44920	LEAD	<1 PPB	15 PPB
64-16A B-2 Sink Faucet	7/22/2016 9:49	8/16/2016	44921	LEAD	5 PPB	15 PPB
64-17A B-2 Drinking Fountain	7/22/2016 9:51	8/16/2016	44922	LEAD	<1 PPB	15 PPB
64-18A B-3 Sink Faucet	7/22/2016 9:53	8/16/2016	44923	LEAD	5 PPB	15 PPB
64-19A B-3 Drinking Fountain	7/22/2016 9:55	8/16/2016	44924	LEAD	<1 PPB	15 PPB
64-20A B-4 Sink Faucet	7/22/2016 9:57	8/16/2016	44925	LEAD	8 PPB	15 PPB
64-21A B-4 Drinking fountain	7/22/2016 9:56	8/16/2016	44926	LEAD	<1 PPB	15 PPB
64-22A B-5 Sink Faucet	7/22/2016 10:01	8/16/2016	44927	LEAD	8 PPB	15 PPB
64-23A B-5 Drinking Fountain	7/22/2016 10:03	8/16/2016	44928	LEAD	<1 PPB	15 PPB
64-24A B-6 Sink Faucet	7/22/2016 10:05	8/16/2016	44929	LEAD	6 PPB	15 PPB
64-25A B-6 Drinking Fountain	7/22/2016 10:07	8/12/2016	44930	LEAD	10 PPB	15 PPB
64-26A Media Center Sink Faucet	7/22/2016 10:09	8/12/2016	44931	LEAD	<1 PPB	15 PPB
64-27A Media Center Drinking Fountain	7/22/2016 10:11	8/12/2016	44932	LEAD	10 PPB	15 PPB
64-28A Media Center Hall Restroom Drinking Fountain	7/22/2016 10:13	8/12/2016	44933	LEAD	<1 PPB	15 PPB
64-29A C-Pod Hall Sink Faucet	7/22/2016 10:16	8/12/2016	44934	LEAD	8 PPB	15 PPB
64-30A C-Pod Hall Drinking Fountain	7/22/2016 10:18	8/12/2016	44935	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-31A C-1 Sink Faucet	7/22/2016 10:20	8/12/2016	44936	LEAD	11 PPB	15 PPB
64-32A C-1 Drinking Fountain	7/22/2016 10:22	8/16/2016	44937	LEAD	<1 PPB	15 PPB
64-33A C-2 Sink Faucet	7/22/2016 10:24	8/12/2016	44938	LEAD	10 PPB	15 PPB
64-34A C-2 Drinking Fountain	7/22/2016 10:26	8/12/2016	44939	LEAD	<1 PPB	15 PPB
64-35A C-3 Sink Faucet	7/22/2016 10:28	8/16/2016	44940	LEAD	9 PPB	15 PPB
64-36A C-3 Drinking Fountain	7/22/2016 10:30	8/16/2016	44941	LEAD	<1 PPB	15 PPB
64-37A C-4 Sink Faucet	7/22/2016 10:32	8/16/2016	44942	LEAD	9 PPB	15 PPB
64-38A c-4 Drinking Fountain	7/22/2016 10:34	8/16/2016	44943	LEAD	<1 PPB	15 PPB
64-39A C-5 Sink Faucet	7/22/2016 10:36	8/16/2016	44944	LEAD	8 PPB	15 PPB
64-40A C-5 Drinking Fountain	7/22/2016 10:38	8/16/2016	44945	LEAD	<1 PPB	15 PPB
64-41A C-6 Sink Faucet	7/22/2016 10:40	8/16/2016	44946	LEAD	10 PPB	15 PPB
64-42A C-6 Drinking Fountain	7/22/2016 10:42	8/16/2016	44947	LEAD	<1 PPB	15 PPB
64-43A A-Pod Hall Sink Faucet	7/22/2016 10:45	8/16/2016	44948	LEAD	9 PPB	15 PPB
64-44A A-Pod Hall Drinking Fountain	7/22/2016 10:47	8/16/2016	44949	LEAD	<1 PPB	15 PPB
64-45A A-1 Sink Faucet	7/22/2016 10:49	8/16/2016	44950	LEAD	6 PPB	15 PPB
64-46A A-1 Drinking Fountain	7/22/2016 10:51	8/16/2016	44951	LEAD	<1 PPB	15 PPB
64-47A A-2 Sink Faucet	7/22/2016 10:53	8/16/2016	44952	LEAD	4 PPB	15 PPB
64-48A A-2 Drinking Fountain	7/22/2016 10:55	8/16/2016	44953	LEAD	<1 PPB	15 PPB
64-49A A-3 Sink Faucet	7/22/2016 10:57	8/16/2016	44954	LEAD	6 PPB	15 PPB
64-50A A-3 Drinking Fountain	7/22/2016 10:59	8/16/2016	44955	LEAD	<1 PPB	15 PPB
64-51A A-4 Sink Faucet	7/22/2016 11:01	8/16/2016	44956	LEAD	5 PPB	15 PPB
64-52A A-4 Drinking Fountain	7/22/2016 11:03	8/16/2016	44957	LEAD	<1 PPB	15 PPB
64-53A A-5 Sink Faucet	7/22/2016 11:05	8/16/2016	44958	LEAD	6 PPB	15 PPB
64-54A A-5 Drinking Fountain	7/22/2016 11:07	8/16/2016	44959	LEAD	<1 PPB	15 PPB
64-55A A-6 Sink Faucet	7/22/2016 11:09	8/16/2016	44960	LEAD	8 PPB	15 PPB
64-56A A-6 Drinking Fountain	7/22/2016 11:11	8/16/2016	44961	LEAD	<1 PPB	15 PPB
64-57A Portable 603 Sink Faucet	7/22/2016 11:15	8/16/2016	44962	LEAD	2 PPB	15 PPB
64-58A Portable 603 Drinking Fountain	7/22/2016 11:17	8/16/2016	44963	LEAD	<1 PPB	15 PPB
64-59A Portable 604 Sink Faucet	7/22/2016 11:19	8/16/2016	44964	LEAD	3 PPB	15 PPB
64-60A Portable 604 Drinking Fountain	7/22/2016 11:21	8/16/2016	44965	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-04B Cafeteria Closet Sink Faucet	7/22/2016 9:22	9/6/2016	53433	LEAD	2 PPB	15 PPB
64-12B B-Pod Hall Sink Faucet	7/22/2016 9:41	9/6/2016	53434	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Yoshikai Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
64-04C Cafeteria Closet Sink Faucet	10/28/2016 6:30	11/1/2016	65998	LEAD	3 PPB	15 PPB
64-12C B-Pod Hall Sink Faucet	10/28/2016 6:34	11/1/2016	65999	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level