

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
27-01A Room 2 Sink Faucet	8/9/16 7:54	8/17/16 12:03	608100001	COPPER	0.0 PPM	1.3 PPM
27-02A Room 2 Drinking Fountain	8/9/16 7:54	8/17/16 12:04	608100002	COPPER	0.1 PPM	1.3 PPM
27-03A Room 1 Sink Faucet	8/9/16 7:58	8/18/16 11:06	608100003	COPPER	0.9 PPM	1.3 PPM
27-04A Room 1 Drinking Fountain	8/9/16 7:58	8/17/16 12:05	608100004	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (E) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03E Room 1 Sink Faucet	4/6/2017 8:37	4/11/2017	18161	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
27-03C Room 1 Sink Faucet	10/21/2016 6:51	10/25/2016	64850	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (G) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03G Room 1 Sink Faucet	9/1/2017 8:40:00AM	9/5/2017	50661	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (I) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03I Room 1 Sink Faucet	12/15/2017 7:30:00AM	12/19/2017	79378	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level