

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
27-01A Room 2 Sink Faucet	8/9/16 7:54	8/17/16 12:03	608100001	LEAD	9 PPB	15 PPB
27-02A Room 2 Drinking Fountain	8/9/16 7:54	8/17/16 12:04	608100002	LEAD	9 PPB	15 PPB
27-03A Room 1 Sink Faucet	8/9/16 7:58	8/17/16 12:04	608100003	LEAD	15 PPB	15 PPB
27-04A Room 1 Drinking Fountain	8/9/16 7:58	8/17/16 12:05	608100004	LEAD	11 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Lead Water Sampling Results
 Flushed (B) Sample Data
 Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
27-03B Room 1 Sink Faucet	8/9/16 7:59 AM	8/312016	608262701	LEAD	4 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (E) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03E Room 1 Sink Faucet	4/6/2017 8:37	4/11/2017	18161	LEAD	93 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
27-03C Room 1 Sink Faucet	10/21/2016 6:51	10/25/2016	64850	LEAD	25 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (D) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
27-03D Room 1 Sink Faucet	10/21/16 6:52 AM	11/3/2016	66345	LEAD	9 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (G) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03G Room 1 Sink Faucet	9/1/2017 8:40:00AM	9/5/2017	50661	LEAD	17 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (I) Sample Data
Jane Goodall Environmental Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
027-03I Room 1 Sink Faucet	12/15/2017 7:30:00AM	12/19/2017	79378	LEAD	7 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level