

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Valley Inquiry School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
056-01A Classroom 5 Sink Faucet	8/4/2016 10:38	8/23/2016	49892	COPPER	0.4 PPM	1.3 PPM
056-02A Classroom 5 Drinking Fountain	8/4/2016 10:38	8/23/2016	49893	COPPER	0.1 PPM	1.3 PPM
056-03A Classroom 4 Sink Faucet	8/4/2016 10:40	8/23/2016	49894	COPPER	0.2 PPM	1.3 PPM
056-04A Classroom 4 Drinking Fountain	8/4/2016 10:40	8/23/2016	49895	COPPER	0.3 PPM	1.3 PPM
056-05A Room 6 Sink Faucet	8/4/2016 10:42	8/23/2016	49896	COPPER	0.1 PPM	1.3 PPM
056-06A Room 6 Drinking Fountain	8/4/2016 10:42	8/23/2016	49897	COPPER	0.1 PPM	1.3 PPM
056-07A Classroom 3 Sink Faucet	8/4/2016 10:44	8/23/2016	49898	COPPER	0.6 PPM	1.3 PPM
056-08A Classroom 3 Drinking Fountain	8/4/2016 10:44	8/23/2016	49899	COPPER	0.2 PPM	1.3 PPM
056-09A Room 7 Sink Faucet	8/4/2016 10:46	8/23/2016	49900	COPPER	0.1 PPM	1.3 PPM
056-10A Room 7 Drinking Fountain	8/4/2016 10:46	8/23/2016	49901	COPPER	0.1 PPM	1.3 PPM
056-11A Room 2 Sink Faucet	8/4/2016 10:48	8/23/2016	49902	COPPER	0.5 PPM	1.3 PPM
056-12A Room 2 Drinking Fountain	8/4/2016 10:48	8/23/2016	49903	COPPER	0.2 PPM	1.3 PPM
056-13A Classroom 1 Sink Faucet	8/4/2016 10:50	8/23/2016	49904	COPPER	0.1 PPM	1.3 PPM
056-14A Classroom 1 Drinking Fountain	8/4/2016 10:50	8/23/2016	49905	COPPER	0.4 PPM	1.3 PPM
056-15A Hallway Drinking Fountain 1	8/4/2016 10:52	8/23/2016	49906	COPPER	0.3 PPM	1.3 PPM
056-16A Health Room Sink Faucet	8/4/2016 10:54	8/23/2016	49907	COPPER	0.1 PPM	1.3 PPM
056-17A Faculty Lounge Sink Faucet	8/4/2016 10:56	8/23/2016	49908	COPPER	0.4 PPM	1.3 PPM
056-18A Kitchen Food Prep Sink Faucet	8/4/2016 10:59	8/23/2016	49909	COPPER	0.1 PPM	1.3 PPM
056-19A Kitchen Food Prep Sink Faucet	8/4/2016 11:01	8/23/2016	49910	COPPER	0.1 PPM	1.3 PPM
056-20A Kitchen Food Prep Sink Faucet	8/4/2016 11:03	8/23/2016	49911	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
Valley Inquiry School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
056-18C Kitchen Food Prep Sink Faucet	10/21/2016 6:32	10/25/2016	64849	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level