

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Barrick Field

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
086-01A Exterior West Drinking Fountain (left)	4/26/2019 6:40	4/29/2019	29708	COPPER	0.6 PPM	1.3 PPM
086-02A Exterior West Drinking Fountain (right)	4/26/2019 6:40	4/29/2019	29709	COPPER	0.6 PPM	1.3 PPM
086-03A Exterior West Bottle Fill	4/26/2019 6:40	4/29/2019	29710	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level