

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Barrick Field

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
086-01A Exterior West Drinking Fountain (left)	4/26/2019 6:40	4/29/2019	29708	LEAD	4 PPB	15 PPB
086-02A Exterior West Drinking Fountain (right)	4/26/2019 6:40	4/29/2019	29709	LEAD	4 PPB	15 PPB
086-03A Exterior West Bottle Fill	4/26/2019 6:40	4/29/2019	29710	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 15 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level