

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Summit CTP Boys and Girls Club

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
087-01A Main Hall to Gym Drinking Fountain	4/26/2019 7:08	4/29/2019	29728	COPPER	0.3 PPM	1.3 PPM
087-02A Kitchen West Wall Sink Faucet	4/26/2019 7:11	4/29/2019	29729	COPPER	0.3 PPM	1.3 PPM
087-03A Kitchen East Wall Sink Faucet	4/26/2019 7:11	4/29/2019	29730	COPPER	0.5 PPM	1.3 PPM
087-04A Main Office Staff Area Sink Faucet	4/26/2019 7:13	4/29/2019	29731	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level