

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Summit CTP Boys and Girls Club

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
087-01A Main Hall to Gym Drinking Fountain	4/26/2019 7:08	4/29/2019	29728	LEAD	<1 PPB	15 PPB
087-02A Kitchen West Wall Sink Faucet	4/26/2019 7:11	4/29/2019	29729	LEAD	<1 PPB	15 PPB
087-03A Kitchen East Wall Sink Faucet	4/26/2019 7:11	4/29/2019	29730	LEAD	<1 PPB	15 PPB
087-04A Main Office Staff Area Sink Faucet	4/26/2019 7:13	4/29/2019	29731	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level