

# INDUSTRIAL HYGIENE REPORT

## RADON TESTING REPORT

### Straub School

Report to: Vonnie B. Good, EHS Salem Keizer School District

By: Kathy Ellis, Senior Industrial Hygiene Consultant

Reviewed By: DeEtta Burrows, MSPH, CIH

On-site: March 20-23, 2017

Report: April 7, 2017

---

#### PURPOSE

After initial testing showed radon levels above EPA's Action Level of 4.0 picoCuries/L (pCi/L) in two rooms at Straub, a radon mitigation system was installed in December of 2013. To ensure that the systems are functioning properly and levels are well below EPA's Action Level, annual radon testing is performed.

#### CONCLUSION

Both tested locations had very low levels of radon.

#### TESTING

Radon testing was conducted using protocols recommended by the Oregon Health Authority per ORS 332.166-.167. Radon Air-Chek short-term test devices were used in the rooms by suspending the device in each room. The testing occurred from March 20-23, 2017, during normal and routine school ventilation system operation, as well as with the radon mitigation system in operation.

Quality assurance testing was also conducted by utilizing blank, duplicate, and spiked samples per the recommendations found in ORS 332.166-.167. The test kits labeled "Check In 1" is the blank. It tested at <0.3 pCi/L, confirming the lab results.

#### EPA RADON GUIDELINES

The EPA has set an Action Level of 4.0 pCi/L (picoCuries per liter) for schools. If classrooms or buildings have radon levels at or above 4.0 pCi/L, EPA recommends that schools take action to reduce the level. These actions include:

Step 1 If your result is 4.0 pCi/L or higher take a follow-up test (Step 2) to be sure.

Step 2. Follow up with either a long-term test or a second short-term test.

The World Health Organization has set their action level at 2.7 pCi/L. Salem Keizer School District has determined that 2.7 pCi/L is a target level where retesting should be done.

## CONTROL OF RADON LEVELS IN SCHOOLS

The major control mechanism for lowering radon levels within school buildings is the use of dilution ventilation. If the amount of outside air delivered into a building increases, the radon levels should decrease. In this case, increased ventilation wasn't sufficient. Therefore, a subslab depressurization system was installed in the Custodial closet near Room 117.

### Sample Data Attached

Radon test result report for:

**SK  
STRAUB**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7854760	117	2017-03-20 @ 9:00 am	2017-03-23 @ 10:00 am	< 0.3	2017-03-24
7854759	117	2017-03-20 @ 9:00 am	2017-03-23 @ 10:00 am	< 0.3	2017-03-24
7854761	118	2017-03-20 @ 9:00 am	2017-03-23 @ 10:00 am	< 0.3	2017-03-24
7854762	CHECK IN 1	2017-03-20 @ 9:00 am	2017-03-23 @ 10:00 am	< 0.3	2017-03-24