

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Lancaster Professional Center - District Main Office

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
82-01A 1st Floor Hall Refrigerated Drinking Fountain Across from Utility Room	8/13/2016 12:10	8/25/2016	50957	LEAD	<1 PPB	15 PPB
82-02A Suite 130 Breakroom Sink Faucet	8/13/2016 12:11	8/25/2016	50958	LEAD	1 PPB	15 PPB
82-03A Suite 102 Breakroom Sink Faucet	8/13/2016 12:14	8/25/2016	50959	LEAD	<1 PPB	15 PPB
82-04A Suite 101 Sink Faucet	8/13/2016 12:16	8/25/2016	50960	LEAD	<1 PPB	15 PPB
82-05A Hall Refrigerated Drinking Fountain at NE Corner	8/13/2016 12:20	8/25/2016	50961	LEAD	<1 PPB	15 PPB
82-06A Suite 220 Sink Faucet Faucet	8/13/2016 12:21	8/25/2016	50962	LEAD	1 PPB	15 PPB
82-07A Employee Breakroom Sink Faucet	8/13/2016 12:23	8/25/2016	50963	LEAD	<1 PPB	15 PPB
82-08A Suite 220 Work Room Sink Faucet	8/13/2016 12:25	8/25/2016	50964	LEAD	4 PPB	15 PPB
82-09A Suite 202 Work Room Sink Faucet	8/13/2016 12:27	8/25/2016	50965	LEAD	2 PPB	15 PPB
82-10A Suite 200 Break Room Sink Faucet	8/13/2016 12:29	8/25/2016	50966	LEAD	<1 PPB	15 PPB
82-11A Suite 200 Break Room Ice Machine	8/13/2016 12:31	8/25/2016	50967	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level