

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Baker Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
069-01A Kitchen Food Prep Sink Faucet	8/4/2016 11:40	8/23/2016	49912	COPPER	0.0 PPM	1.3 PPM
069-02A Hallway Drinking Fountain 1	8/4/2016 11:42	8/23/2016	49913	COPPER	0.0 PPM	1.3 PPM
069-03A Staff Lounge Sink faucet	8/4/2016 11:44	8/23/2016	49914	COPPER	0.0 PPM	1.3 PPM
069-04A Classroom 1 Sink Faucet	8/4/2016 11:46	8/23/2016	49915	COPPER	0.0 PPM	1.3 PPM
069-05A Classroom 2 Sink Faucet	8/4/2016 11:48	8/23/2016	49916	COPPER	0.0 PPM	1.3 PPM
069-06A Classroom 2 Drinking Fountain	8/4/2016 11:48	8/23/2016	49917	COPPER	0.0 PPM	1.3 PPM
069-07A Classroom 3 Sink Faucet	8/4/2016 11:51	8/23/2016	49918	COPPER	0.0 PPM	1.3 PPM
069-08A Classroom 3 Drinking Fountain	8/4/2016 11:51	8/23/2016	49919	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level