

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Baker Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
069-01A Kitchen Food Prep Sink Faucet	8/4/2016 11:40	8/23/2016	49912	LEAD	2 PPB	15 PPB
069-02A Hallway Drinking Fountain 1	8/4/2016 11:42	8/23/2016	49913	LEAD	5 PPB	15 PPB
069-03A Staff Lounge Sink faucet	8/4/2016 11:44	8/23/2016	49914	LEAD	3 PPB	15 PPB
069-04A Classroom 1 Sink Faucet	8/4/2016 11:46	8/23/2016	49915	LEAD	5 PPB	15 PPB
069-05A Classroom 2 Sink Faucet	8/4/2016 11:48	8/23/2016	49916	LEAD	1 PPB	15 PPB
069-06A Classroom 2 Drinking Fountain	8/4/2016 11:48	8/23/2016	49917	LEAD	9 PPB	15 PPB
069-07A Classroom 3 Sink Faucet	8/4/2016 11:51	8/23/2016	49918	LEAD	6 PPB	15 PPB
069-08A Classroom 3 Drinking Fountain	8/4/2016 11:51	8/23/2016	49919	LEAD	1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level