

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-01A Classroom 2 Sink Faucet	7/20/2016 12:35	7/27/2016	42850	COPPER	0.3 PPM	1.3 PPM
66-02A Activity Room Drinking Fountain	7/20/2016 12:37	7/27/2016	42851	COPPER	0.0 PPM	1.3 PPM
66-03A Activity Room Sink Faucet	7/20/2016 12:39	7/27/2016	42852	COPPER	0.1 PPM	1.3 PPM
66-04A Classroom 1 Sink Faucet	7/20/2016 12:42	7/27/2016	42853	COPPER	0.1 PPM	1.3 PPM
66-05A Classroom 1 Drinking Fountain	7/20/2016 12:44	7/27/2016	42854	COPPER	0.0 PPM	1.3 PPM
66-06A Front Entry Drinking Fountain	7/20/2016 12:46	7/27/2016	42855	COPPER	0.0 PPM	1.3 PPM
66-07A Media Room Sink Faucet	7/20/2016 12:54	7/27/2016	42856	COPPER	0.4 PPM	1.3 PPM
66-08A Modular Classroom 3 Sink Faucet	7/20/2016 12:57	7/27/2016	42857	COPPER	0.5 PPM	1.3 PPM
66-09A Modular Classroom 3 Drinking Fountain	7/20/2016 12:59	7/27/2016	42858	COPPER	0.7 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-02C Activity Room Drinking Fountain	1/20/2017 6:51	1/23/2017	3137	COPPER	0.0 PPM	1.3 PPM
66-03C Activity Room Sink Faucet	1/20/2017 6:53	1/23/2017	3138	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (E) Sample Data
Bethel Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
66-03E Activity Room Sink Faucet	8/14/2018 8:10	8/17/2018	61418	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level