

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Bethel Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 66-01A Classroom 2 Sink Faucet | 7/20/2016 12:35 | 7/27/2016 | 42850 | LEAD | 10 PPB | 15 PPB |
| 66-02A Activity Room Drinking Fountain | 7/20/2016 12:37 | 7/27/2016 | 42851 | LEAD | 23 PPB | 15 PPB |
| 66-03A Activity Room Sink Faucet | 7/20/2016 12:39 | 7/27/2016 | 42852 | LEAD | 15 PPB | 15 PPB |
| 66-04A Classroom 1 Sink Faucet | 7/20/2016 12:42 | 7/27/2016 | 42853 | LEAD | 4 PPB | 15 PPB |
| 66-05A Classroom 1 Drinking Fountain | 7/20/2016 12:44 | 7/27/2016 | 42854 | LEAD | 1 PPB | 15 PPB |
| 66-06A Front Entry Drinking Fountain | 7/20/2016 12:46 | 7/27/2016 | 42855 | LEAD | 10 PPB | 15 PPB |
| 66-07A Media Room Sink Faucet | 7/20/2016 12:54 | 7/27/2016 | 42856 | LEAD | 5 PPB | 15 PPB |
| 66-08A Modular Classroom 3 Sink Faucet | 7/20/2016 12:57 | 7/27/2016 | 42857 | LEAD | <1 PPB | 15 PPB |
| 66-09A Modular Classroom 3 Drinking Fountain | 7/20/2016 12:59 | 7/27/2016 | 42858 | LEAD | <1 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Bethel Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 66-02B Activity Room Drinking Fountain | 7/20/2016 12:38 | 9/6/2016 | 53423 | LEAD | 3 PPB | 15 PPB |
| 66-03B Activity Room Sink Faucet | 7/20/2016 12:40 | 9/6/2016 | 53424 | LEAD | 2 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Bethel Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 66-02C Activity Room Drinking Fountain | 1/20/2017 6:51 | 1/23/2017 | 3137 | LEAD | 9 PPB | 15 PPB |
| 66-03C Activity Room Sink Faucet | 1/20/2017 6:53 | 1/23/2017 | 3138 | LEAD | 21 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (E) Sample Data
Bethel Elementary School

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--------------------------------------|-------------------|---------------|--------------|------------|---------|--------------|
| 66-03E Activity Room Sink Faucet | 8/14/2018 8:10 | 8/17/2018 | 61418 | LEAD | 2 PPB | 15 PPB |

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level