

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-01A Sink Faucet by Sprinkler Control Room	8/6/16 10:57	8/14/2016	1608471-01A	COPPER	0.3 PPM	1.3 PPM
71-02A Test Kitchen Triple Basin Sink Faucet (Left)	8/6/16 11:01	8/14/2016	1608471-02A	COPPER	0.3 PPM	1.3 PPM
71-03A Test Kitchen Triple Basin Sink Faucet (Right)	8/6/16 11:01	8/14/2016	1608471-03A	COPPER	0.4 PPM	1.3 PPM
71-04A Mixing Basin Faucet	8/6/16 11:02	8/14/2016	1608471-04A	COPPER	0.4 PPM	1.3 PPM
71-05A Catering Sink Faucet	8/6/16 11:03	8/14/2016	1608471-05A	COPPER	0.4 PPM	1.3 PPM
71-06A Break Room Sink Faucet	8/6/16 11:04	8/14/2016	1608471-06A	COPPER	0.4 PPM	1.3 PPM
71-07A Hall by Fire Alarm Room Drinking Fountain	8/6/16 11:08	8/14/2016	1608471-07A	COPPER	0.7 PPM	1.3 PPM
71-08A Loading Dock Ice Maker	8/6/16 11:10	8/14/2016	1608471-08A	COPPER	0.0 PPM	1.3 PPM
71-09A Prep Area Sink Faucet	8/6/16 11:14	8/10/2016	1608471-09A	COPPER	0.3 PPM	1.3 PPM
71-10A Prep Area Sink Faucet	8/6/16 11:14	8/10/2016	1608471-10A	COPPER	0.3 PPM	1.3 PPM
71-11A Prep Area Hand Wash Sink Faucet	8/6/16 11:17	8/10/2016	1608471-11A	COPPER	0.3 PPM	1.3 PPM
71-12A Food Prep Double Sink Faucet	8/6/16 11:17	8/10/2016	1608471-12A	COPPER	0.3 PPM	1.3 PPM
71-13A Food Prep Area Left Triple Sink Faucet	8/6/16 11:21	8/10/2016	1608471-13A	COPPER	0.3 PPM	1.3 PPM
71-14A Food Prep Area Right Triple Sink Faucet	8/6/16 11:21	8/10/2016	1608471-14A	COPPER	0.1 PPM	1.3 PPM
71-15A Mixer Faucet	8/6/16 11:24	8/14/2016	1608471-15A	COPPER	0.6 PPM	1.3 PPM
71-16A Middle of Food Prep Sink Faucet	8/6/16 11:26	8/14/2016	1608471-16A	COPPER	0.3 PPM	1.3 PPM
71-17A Food Prep Hand Wash Sink Faucet	8/6/16 11:26	8/10/2016	1608471-17A	COPPER	0.5 PPM	1.3 PPM
71-18A Food Prep Vat Faucet	8/6/16 11:28	8/11/2016	1608471-18A	COPPER	1.4 PPM	1.3 PPM
71-19A Island Catering Kitchen Sink Faucet	8/6/16 11:29	8/14/2016	1608471-19A	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-18C Food Prep Vat Faucet	9/22/2016 4:30	9/26/2016	57959	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-18B Food Prep Vat Faucet	8/6/16 11:29	8/26/2016	1608472-17A	COPPER	0.7 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
Central Kitchen

Sampled Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
71-13C Food Prep Area Left Triple Sink Faucet	9/14/2016 4:49	9/15/2016	55817	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level