

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Career Technical Education Center (CTEC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
73-01A Main Office Sink	8/6/2016 8:35	8/23/2016	49927	COPPER	0.3 PPM	1.3 PPM
73-02A Main Office Fridge Ice maker	8/6/2016 8:35	8/23/2016	49928	COPPER	0.0 PPM	1.3 PPM
73-03A Manufacturing Drinking fountain	8/6/2016 8:40	8/23/2016	49929	COPPER	0.6 PPM	1.3 PPM
73-04A Construction Drinking Fountain	8/6/2016 8:41	8/23/2016	49930	COPPER	0.7 PPM	1.3 PPM
73-05A Outside Kitchen Drinking Fountain	8/6/2016 8:47	8/23/2016	49931	COPPER	0.0 PPM	1.3 PPM
73-06A Outside Kitchen Bottle Filler	8/6/2016 8:47	8/23/2016	49932	COPPER	0.0 PPM	1.3 PPM
73-07A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49933	COPPER	0.0 PPM	1.3 PPM
73-08A Room 201 Drinking Fountain	8/6/2016 8:43	8/23/2016	49934	COPPER	0.0 PPM	1.3 PPM
73-09A Room 201 Bottle Refill	8/6/2016 8:44	8/23/2016	49935	COPPER	0.0 PPM	1.3 PPM
73-10A Art Room Sink Faucet (Left)	8/6/2016 9:04	8/23/2016	49936	COPPER	0.5 PPM	1.3 PPM
73-11A Art Room Sink Faucet (Right)	8/6/2016 9:04	8/23/2016	49937	COPPER	0.1 PPM	1.3 PPM
73-12A Room 117 -Sink Faucet	8/6/2016 9:10	8/23/2016	49938	COPPER	0.1 PPM	1.3 PPM
73-13A Cosmetology Lobby Drinking Fountain	8/6/2016 8:51	8/23/2016	49939	COPPER	0.0 PPM	1.3 PPM
73-14A Cosmetology Lobby Drinking Fountain	8/6/2016 8:52	8/23/2016	49940	COPPER	0.0 PPM	1.3 PPM
73-15A Cosmetology Lobby Bottle Refill	8/6/2016 8:52	8/23/2016	49941	COPPER	0.0 PPM	1.3 PPM
73-16A Facial Room Sink Faucet	8/6/2016 9:13	8/23/2016	49942	COPPER	0.0 PPM	1.3 PPM
73-17A Cosmetogy Room Sink Faucet	8/6/2016 9:14	8/23/2016	49943	COPPER	0.0 PPM	1.3 PPM
73-18A Cosmetology Classroom Sink Faucet	8/6/2016 9:15	8/23/2016	49944	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Career Technical Education Center (CTEC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
073-19A Commons Goose-Neck Sink Faucet	8/14/2018 8:55	8/17/2018	61436	COPPER	0.6 1.3	PPM
073-20A Law/Court Rm Sink Faucet	8/14/2018 9:03	8/17/2018	61437	COPPER	0.1 1.3	PPM
073-21A Law/Safety Rm Left Sink Faucet	8/14/2018 9:05	8/17/2018	61438	COPPER	0.3 1.3	PPM
073-22A Law/Safety Rm Right Sink Faucet	8/14/2018 9:06	8/17/2018	61439	COPPER	0.1 1.3	PPM
073-23A Law/Scenario Rm Left Drinking Fountain	8/14/2018 9:10	8/17/2018	61440	COPPER	<0.1 1.3	PPM
073-24A Law/Scenario Rm Drinking Fountain w/25	8/14/2018 9:11	8/17/2018	61441	COPPER	0.1 1.3	PPM
073-25A Law/Scenario Rm Bottle Fill w/24	8/14/2018 9:09	8/17/2018	61442	COPPER	0.1 1.3	PPM
073-26A Law/Scenario Rm Left Sink Faucet	8/14/2018 9:13	8/17/2018	61443	COPPER	<0.1 1.3	PPM
073-27A Law/Scenario Rm Right Sink Faucet	8/14/2018 9:15	8/17/2018	61444	COPPER	0.1 1.3	PPM
073-28A Staff Lounge Sink Faucet	8/14/2018 8:57	8/17/2018	61445	COPPER	0.1 1.3	PPM
073-29A Science Rm Sink Faucet	8/14/2018 9:00	8/17/2018	61446	COPPER	<0.1 1.3	PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Career Technical Education Center (CTEC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
073-30A Auto Body Classroom Left Sink Faucet	8/27/2018 19:50	8/29/2018	64882	COPPER	0.1 1.3	PPM
073-31A Auto Body Classroom Right Sink Faucet	8/27/2018 19:53	8/29/2018	64883	COPPER	0.1 1.3	PPM
073-32A Auto Body Shop By Classroom Sink Faucet	8/27/2018 19:56	8/29/2018	64884	COPPER	0.1 1.3	PPM
073-33A Auto Body Shop by Hall Sink Faucet	8/27/2018 20:00	8/29/2018	64885	COPPER	0.1 1.3	PPM
073-34A Classroom By Auto Body Sink Faucet	8/27/2018 20:06	8/29/2018	64886	COPPER	0.0 1.3	PPM
073-35A CNC Lab/Shop Left Sink Faucet	8/27/2018 20:09	8/29/2018	64887	COPPER	0.1 1.3	PPM
073-36A CNC Lab/Shop Right Sink Faucet	8/27/2018 20:11	8/29/2018	64888	COPPER	<0.1 1.3	PPM
073-37A Drone/Robotics Lab Island Sink Faucet	8/27/2018 20:13	8/29/2018	64889	COPPER	0.1 1.3	PPM
073-38A Drone/Robotics Lab Left Sink Faucet	8/27/2018 20:15	8/29/2018	64890	COPPER	0.1 1.3	PPM
073-39A Drone/Robotics Lab Right Sink Faucet	8/27/2018 20:17	8/29/2018	64891	COPPER	0.1 1.3	PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level