

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Downtown Learning Center (DTLC)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
83-01A Staff Room Sink Faucet	7/29/2016 9:35	8/23/2016	49973	LEAD	11 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level