

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Fruitland Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
068-01A Classroom 3 Sink Faucet	7/21/2016 10:30	7/28/2016	43566	LEAD	2 PPB	15 PPB
068-02A Classroom 4 Sink Faucet	7/21/2016 10:32	7/28/2016	43567	LEAD	9 PPB	15 PPB
068-03A Classroom 2 Sink Faucet	7/21/2016 10:35	7/28/2016	43568	LEAD	6 PPB	15 PPB
068-04A Classroom 2 Drinking Fountain	7/21/2016 10:37	7/28/2016	43569	LEAD	2 PPB	15 PPB
068-05A Classroom 1 Sink Faucet	7/21/2016 10:40	7/28/2016	43570	LEAD	<1 PPB	15 PPB
068-06A Hallway Drinking Fountain 1	7/21/2016 10:42	7/28/2016	43571	LEAD	1 PPB	15 PPB
068-07A Hallway Drinking Fountain 2	7/21/2016 10:44	7/28/2016	43572	LEAD	2 PPB	15 PPB
068-08A Staff Kitchen/Break Sink Faucet	7/21/2016 10:47	7/28/2016	43573	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level