

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (A) Sample Data  
 Howard Street Charter School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-11A Room B-3 Sink Faucet (Left)	7/30/16 1:01 PM	8/5/2016	1608182-11A	LEAD	<1.0 PPB	15 PPB
50-12A Room B-3 Sink Faucet (Right)	7/30/16 1:01 PM	8/5/2016	1608182-12A	LEAD	1 PPB	15 PPB
50-13A Auxillary Gymnasium Drinking Fountain	7/30/16 1:44 PM	8/7/2016	1608182-13A	LEAD	10 PPB	15 PPB
50-14A Room 100 Sink Faucet	7/30/16 1:46 PM	8/5/2016	1608182-14A	LEAD	<1.0 PPB	15 PPB
50-15A Room 185 Sink Faucet	7/30/16 1:53 PM	8/5/2016	1608182-15A	LEAD	2 PPB	15 PPB
50-16A Hall Drinking Fountain 1	7/30/16 1:52 PM	8/6/2016	1608182-16A	LEAD	1 PPB	15 PPB
50-17A Room 182 Sink Faucet	7/30/16 1:48 PM	8/6/2016	1608182-17A	LEAD	2 PPB	15 PPB
50-18A Hall Drinking Fountain 2	7/30/16 1:50 PM	8/6/2016	1608182-18A	LEAD	<1.0 PPB	15 PPB
50-19A Staff Room Sink Faucet (Left)	7/30/16 1:55 PM	8/6/2016	1608182-19A	LEAD	<1.0 PPB	15 PPB
50-20A Staff Room Sink Faucet (Right)	7/30/16 1:55 PM	8/6/2016	1608182-20A	LEAD	<1.0 PPB	15 PPB
50-73A 2nd Hall Drinking Fountain 13	7/30/16 4:00 PM	8/6/2016	1608182-72A	LEAD	5 PPB	15 PPB
50-74A 2nd Floor Hall Drinking Fountain 14	7/30/16 4:03 PM	8/6/2016	1608182-73A	LEAD	5 PPB	15 PPB
50-75A 2nd Floor Hall Drinking Fountain 15	7/30/16 4:03 PM	8/6/2016	1608182-74A	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Howard Street Charter School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-21A Auditorium Hall Drinking Fountain	9/29/2016 5:21	10/3/2016	59450	LEAD	26 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Howard Street Charter School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-21B Auditorium Hall Drinking Fountain	9/29/2016 5:22	10/18/2016	63611	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Howard Street Charter School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-21C Auditorium Hall Drinking Fountain	1/20/2017 5:24	1/23/2017	3127	LEAD	3 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level