

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Lancaster Professional Center - District Main Office

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
82-01A 1st Floor Hall Refrigerated Drinking Fountain Across from Utility Room	8/13/2016 12:10	8/25/2016	50957	COPPER	0.3 PPM	1.3 PPM
82-02A Suite 130 Breakroom Sink Faucet	8/13/2016 12:11	8/25/2016	50958	COPPER	0.2 PPM	1.3 PPM
82-03A Suite 102 Breakroom Sink Faucet	8/13/2016 12:14	8/25/2016	50959	COPPER	0.2 PPM	1.3 PPM
82-04A Suite 101 Sink Faucet	8/13/2016 12:16	8/25/2016	50960	COPPER	0.1 PPM	1.3 PPM
82-05A Hall Refrigerated Drinking Fountain at NE Corner	8/13/2016 12:20	8/25/2016	50961	COPPER	0.5 PPM	1.3 PPM
82-06A Suite 220 Sink Faucet Faucet	8/13/2016 12:21	8/25/2016	50962	COPPER	0.5 PPM	1.3 PPM
82-07A Employee Breakroom Sink Faucet	8/13/2016 12:23	8/25/2016	50963	COPPER	0.4 PPM	1.3 PPM
82-08A Suite 220 Work Room Sink Faucet	8/13/2016 12:25	8/25/2016	50964	COPPER	0.2 PPM	1.3 PPM
82-09A Suite 202 Work Room Sink Faucet	8/13/2016 12:27	8/25/2016	50965	COPPER	0.4 PPM	1.3 PPM
82-10A Suite 200 Break Room Sink Faucet	8/13/2016 12:29	8/25/2016	50966	COPPER	0.5 PPM	1.3 PPM
82-11A Suite 200 Break Room Ice Machine	8/13/2016 12:31	8/25/2016	50967	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level