

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
McKay Annex

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
76-01A Hall by Computer Drinking Fountain #1	8/13/2016 9:00	8/25/2016	51338	COPPER	0.4 PPM	1.3 PPM
76-02A Hall by Computer Drinking Fountain #2	8/13/2016 9:02	8/25/2016	51339	COPPER	0.3 PPM	1.3 PPM
76-03A Teachers Lounge Sink Faucet	8/13/2016 9:10	8/25/2016	51340	COPPER	0.1 PPM	1.3 PPM
76-04A Teachers Lounge Ice Maker	8/13/2016 9:12	8/25/2016	51341	COPPER	0.5 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level