

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
McKay Annex

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
76-01A Hall by Computer Drinking Fountain #1	8/13/2016 9:00	8/25/2016	51338	LEAD	3 PPB	15 PPB
76-02A Hall by Computer Drinking Fountain #2	8/13/2016 9:02	8/25/2016	51339	LEAD	4 PPB	15 PPB
76-03A Teachers Lounge Sink Faucet	8/13/2016 9:10	8/25/2016	51340	LEAD	6 PPB	15 PPB
76-04A Teachers Lounge Ice Maker	8/13/2016 9:12	8/25/2016	51341	LEAD	16 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level