

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Olinger

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
85-01A Main Room Drinking Fountain w/02	4/11/2019 6:25	4/12/2019	25267	COPPER	0.0 PPM	1.3 PPM
85-02A Main Room Bottle Fill w/01	4/11/2019 6:28	4/12/2019	25268	COPPER	0.0 PPM	1.3 PPM
85-03A Main Room Drinking Fountain (left)	4/11/2019 6:45	4/12/2019	25269	COPPER	0.0 PPM	1.3 PPM
85-04A Small Room Off South Lobby Sink Faucet	4/11/2019 6:48	4/12/2019	25270	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Olinger Pool

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
85-05A Hose Bib: Main Room SE Corner	7/18/2019 6:15	7/22/2019	51801	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level