

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Olinger

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
85-01A Main Room Drinking Fountain w/02	4/11/2019 6:25	4/12/2019	25267	LEAD	<1 PPB	15 PPB
85-02A Main Room Bottle Fill w/01	4/11/2019 6:28	4/12/2019	25268	LEAD	<1 PPB	15 PPB
85-03A Main Room Drinking Fountain (left)	4/11/2019 6:45	4/12/2019	25269	LEAD	<1 PPB	15 PPB
85-04A Small Room Off South Lobby Sink Faucet	4/11/2019 6:48	4/12/2019	25270	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Olinger Pool

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
85-05A Hose Bib: Main Room SE Corner	7/18/2019 6:15	7/22/2019	51801	LEAD	6 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level