

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Paulus/Repo/Tech

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
77-01A West End Hallway Drinking Fountain	8/6/2016 7:25	8/23/2016	49986	LEAD	11 PPB	15 PPB
77-02A Room 108 Kitchenette Sink Faucet	8/6/2016 7:27	8/23/2016	49987	LEAD	<1 PPB	15 PPB
77-03A Hallway Drinking Fountain	8/6/2016 7:29	8/23/2016	49988	LEAD	<1 PPB	15 PPB
77-04A 2nd Floor Halway Drinking Fountain	8/6/2016 7:31	8/23/2016	49989	LEAD	2 PPB	15 PPB
77-05A Room 210 Kitchenette Sink Faucet	8/6/2016 7:34	8/23/2016	49990	LEAD	2 PPB	15 PPB
77-06A 2nd Floor Lunch Room Sink Faucet	8/6/2016 7:36	8/23/2016	49991	LEAD	4 PPB	15 PPB
77-07A 2nd Floor West Hall Drinking Fountain	8/6/2016 7:39	8/23/2016	49992	LEAD	33 PPB	15 PPB
77-08A Main Office Sink Faucet	8/6/2016 8:01	8/23/2016	49993	LEAD	<1 PPB	15 PPB
77-09A Print Shop Sink Faucet	8/6/2016 8:03	8/23/2016	49994	LEAD	<1 PPB	15 PPB
77-10A Breakroom Hall Drinking Fountain	8/6/2016 8:05	8/23/2016	49995	LEAD	<1 PPB	15 PPB
77-11A Breakroom Sink Faucet	8/6/2016 8:07	8/23/2016	49996	LEAD	<1 PPB	15 PPB
77-12A Main Office Sink Faucet	8/6/2016 7:50	8/23/2016	49997	LEAD	4 PPB	15 PPB
77-13A Breakroom Sink Faucet	8/6/2016 7:53	8/23/2016	49998	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Paulus/Repo/Tech

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
77-07B 2nd Floor West Hall Drinking Fountain	8/6/2016 7:40	9/6/2016	53429	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (C) Sample Data
Paulus

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
077-07C 2nd Floor West Hall Drinking Fountain	1/20/2017 5:41	1/23/2017	3130	LEAD	12 PPB	15 PPB
077-14C Paulus Office 101 Sink Faucet in Closet	1/20/2017 5:44	1/23/2017	3131	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Paulus/Repo/Tech

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
77-14A Paulus Office 101 Sink Faucet in Closet	10/20/2016 6:47	10/21/2016	64454	LEAD	15 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Paulus

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
077-14B Paulus: Office 101 Sink Faucet in Closet	10/20/2016 6:48	11/3/2016	66344	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level