

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Ratcliff (Summit View Apartments)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
78-01A Kitchen Sink Faucet	8/5/2016 12:00	8/23/2016	49982	COPPER	0.0 PPM	1.3 PPM
78-02A Bathroom Sink Faucet	8/5/2016 12:02	8/23/2016	49983	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level