

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Ratcliff (Summit View Apartments)

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
78-01A Kitchen Sink Faucet	8/5/2016 12:00	8/23/2016	49982	LEAD	<1 PPB	15 PPB
78-02A Bathroom Sink Faucet	8/5/2016 12:02	8/23/2016	49983	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level