

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
1115 Commercial Street

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
81-01A Kitchen Food Prep Sink faucet	8/2/2016 5:03	8/23/2016	49963	COPPER	0.4 PPM	1.3 PPM
81-02A Kitchen Food Prep Sink faucet	8/2/2016 5:05	8/23/2016	49964	COPPER	0.1 PPM	1.3 PPM
81-03A Kitchen Food Prep Sink faucet	8/2/2016 5:07	8/23/2016	49965	COPPER	0.9 PPM	1.3 PPM
81-04A Refrigerated Drinking Fountain 1	8/2/2016 5:09	8/23/2016	49966	COPPER	0.1 PPM	1.3 PPM
81-06A Kitchen 109 Sink Faucet	8/2/2016 5:08	8/23/2016	49967	COPPER	0.1 PPM	1.3 PPM
81-07A Kitchen 108 Sink Faucet	8/2/2016 5:10	8/23/2016	49968	COPPER	0.1 PPM	1.3 PPM
81-09A Refrigerated Drinking Fountain 2	8/2/2016 5:15	8/23/2016	49969	COPPER	0.1 PPM	1.3 PPM
81-10A Bottle Refill at Drinking Fountain 2	8/2/2016 5:15	8/23/2016	49970	COPPER	0.1 PPM	1.3 PPM
81-11A Refrigerated Drinking Fountain 3	8/2/2016 5:15	8/23/2016	49971	COPPER	0.1 PPM	1.3 PPM
81-12A Faculty Lounge Sink Faucet	8/2/2016 5:18	8/23/2016	49972	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
1115 Commercial Street

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
81-05A Kitchen 109 Refrigerator Ice Maker	9/23/2016 4:53	9/26/2016	58312	COPPER	0.1 PPM	1.3 PPM
81-08A Kitchen 108 Refrigerator Water Dispenser	9/23/2016 4:55	9/26/2016	58313	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level