

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
1115 Commercial Street

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
81-01A Kitchen Food Prep Sink faucet	8/2/2016 5:03	8/23/2016	49963	LEAD	<1 PPB	15 PPB
81-02A Kitchen Food Prep Sink faucet	8/2/2016 5:05	8/23/2016	49964	LEAD	<1 PPB	15 PPB
81-03A Kitchen Food Prep Sink faucet	8/2/2016 5:07	8/23/2016	49965	LEAD	1 PPB	15 PPB
81-04A Refrigerated Drinking Fountain 1	8/2/2016 5:09	8/23/2016	49966	LEAD	<1 PPB	15 PPB
81-06A Kitchen 109 Sink Faucet	8/2/2016 5:08	8/23/2016	49967	LEAD	<1 PPB	15 PPB
81-07A Kitchen 108 Sink Faucet	8/2/2016 5:10	8/23/2016	49968	LEAD	<1 PPB	15 PPB
81-09A Refrigerated Drinking Fountain 2	8/2/2016 5:15	8/23/2016	49969	LEAD	<1 PPB	15 PPB
81-10A Bottle Refill at Drinking Fountain 2	8/2/2016 5:15	8/23/2016	49970	LEAD	<1 PPB	15 PPB
81-11A Refrigerated Drinking Fountain 3	8/2/2016 5:15	8/23/2016	49971	LEAD	<1 PPB	15 PPB
81-12A Faculty Lounge Sink Faucet	8/2/2016 5:18	8/23/2016	49972	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
1115 Commercial Street

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
81-05A Kitchen 109 Refrigerator Ice Maker	9/23/2016 4:53	9/26/2016	58312	LEAD	<1 PPB	15 PPB
81-08A Kitchen 108 Refrigerator Water Dispenser	9/23/2016 4:55	9/26/2016	58313	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level