

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Straub Environmental Learning Center

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
084-01A Main Entry Drinking Fountain (Right)	9/14/2016 5:20	9/15/2016	55829	LEAD	3 PPB	15 PPB
084-02A Main Entry Drinking Fountain (Left)	9/14/2016 5:20	9/15/2016	55831	LEAD	2 PPB	15 PPB
084-03A Work/Storage Room Sink Faucet	9/14/2016 5:25	9/15/2016	55833	LEAD	4 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level