

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Student Services

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
79-01A Bathroom Sink Break Faucet Area	8/13/2016 11:50	8/25/2016	50940	COPPER	0.4 PPM	1.3 PPM
79-02A Main Break Area Water Area Next to Sink	8/13/2016 11:54	8/25/2016	50941	COPPER	0.0 PPM	1.3 PPM
79-03A Main Break Area Sink Faucet	8/13/2016 11:56	8/25/2016	50942	COPPER	0.3 PPM	1.3 PPM
79-04A Hall by Restrooms Drinking Fountain	8/13/2016 11:53	8/25/2016	50943	COPPER	0.6 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**