

Salem-Keizer Public Schools
 Lead Water Sampling Results
 First Draw (A) Sample Data
 Transportation Department Building

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
67-01A Parts Room Drinking Fountain	7/23/2016 10:05	7/28/2016	43576	LEAD	<1 PPB	15 PPB
67-02A North Shop Sink Faucet	7/23/2016 10:07	7/28/2016	43577	LEAD	<1 PPB	15 PPB
67-03A North Shop Drinking Fountain	7/23/2016 10:09	7/28/2016	43578	LEAD	25 PPB	15 PPB
67-04A South Shop Sink Faucet	7/23/2016 10:11	7/28/2016	43579	LEAD	2 PPB	15 PPB
67-05A 1st Floor Break Room Sink Faucet	7/23/2016 10:13	7/28/2016	43580	LEAD	<1 PPB	15 PPB
67-06A 2nd Floor Hall Drinking Fountain	7/23/2016 10:15	7/28/2016	43581	LEAD	4 PPB	15 PPB
67-07A 2nd Floor Break Room Sink Faucet	7/23/2016 10:17	7/28/2016	43582	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Transportation Department Building

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
67-03B North Shop Drinking Fountain	7/23/2016 10:10	9/6/2016	53432	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level