

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Triangle Square Program

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
80-01A Restroom Sink Faucet	8/5/2016 11:49	8/23/2016	49984	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level