

Salem-Keizer Public Schools
 Copper Water Sampling Results
 First Draw (A) Sample Data
 Straub Environmental Learning Center

| Sample Identification # and Location | Date/Time Sampled | Date Analyzed | Container ID | Tested For | Results | Action Level |
|--|-------------------|---------------|--------------|------------|---------|--------------|
| 084-01A Main Entry Drinking Fountain (Right) | 9/14/2016 5:20 | 9/15/2016 | 55829 | COPPER | 0.6 PPM | 1.3 PPM |
| 084-02A Main Entry Drinking Fountain (Left) | 9/14/2016 5:20 | 9/15/2016 | 55831 | COPPER | 0.6 PPM | 1.3 PPM |
| 084-03A Work/Storage Room Sink Faucet | 9/14/2016 5:25 | 9/15/2016 | 55833 | COPPER | 0.6 PPM | 1.3 PPM |

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level