

Radon test result report for:**GRANT
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9601935	110	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601936	120	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601937	120 A	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.0 ± 0.9	2021-11-22
9601938	140	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601939	160	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.5 ± 0.9	2021-11-22
9601941	180 N	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	0.8 ± 0.9	2021-11-22
9601940	180 S	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601950	CAFETERIA E	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601951	CAFETERIA W	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601925	CONF RM	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601954	COUNSELOR	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601923	CSOC	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601931	GYME	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.3 ± 1.0	2021-11-22
9601949	KITCHEN OFFICE	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601957	LRC	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601958	LRC OFFICE 1	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601959	LRC OFFICE 2	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601955	LRC SPEECH	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601956	LRC TESTING	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601924	MAIN OFFICE	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601943	MEDIA E	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601942	MEDIA W	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.3 ± 0.9	2021-11-22
9601932	MUSIC	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601930	PE OFFICE	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601922	PRINICIPAL	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601964	QCB 1	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601965	QCB 2	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601953	READING ROOM	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.2 ± 0.9	2021-11-22
9601946	RM 1	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601963	RM 10	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601934	RM 12	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601945	RM 2	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601948	RM 3 E	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601947	RM 3 W	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601944	RM 4	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601926	RM 5	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	2.1 ± 1.0	2021-11-22
9601960	RM 6	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22

November 22, 2021

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**GRANT
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9601927	RM 7	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601962	RM 8 E	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601961	RM 8 W	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601928	RM 9	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	< 0.3	2021-11-22
9601952	STAFF RM	2021-11-09 @ 12:00 pm	2021-11-12 @ 11:00 am	1.4 ± 0.9	2021-11-22

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498