

Auburn Elementary School - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	728
School Name:	Auburn Elementary School
Building ID #:	21420100

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level of 15 ppb
Main office, Health Room, Staff Faucet	21420100-001SF	2022-05-26	21420100-001SF22A	<1	No
Main Office, Workroom 15, Staff Faucet	21420100-002SF	2022-05-26	21420100-002SF22A	<1	No
Music Room 92, Classroom Faucet	21420100-003CF	2022-05-26	21420100-003CF22A	<1	No
Music Room 92, Drinking Water Fountain	21420100-004DW	2022-05-26	21420100-004DW22A	<1	No
Gym, Drinking Water Fountain (behind red mat)	21420100-005DW	2022-05-26	21420100-005DW22A	6.8	No
Multi-Purpose Room 95, Left Drinking Water Fountain	21420100-006DW	2022-05-26	21420100-006DW22A	<1	No
Multi-Purpose Room 95, Right Drinking Water Fountain	21420100-007DW	2022-05-26	21420100-007DW22A	<1	No
Multi-Purpose Room 95, Water Bottle Filler	21420100-008WB	2022-05-26	21420100-008WB22A	<1	No
Classroom 19, Classroom Faucet	21420100-009CF	2022-05-26	21420100-009CF22A	<1	No
Classroom 19, Drinking Water Fountain	21420100-010DW	2022-05-26	21420100-010DW22A	<1	No
Classroom 21, Classroom Faucet	21420100-011CF	2022-05-26	21420100-011CF22A	<1	No
Classroom 21, Drinking Water Fountain	21420100-012DW	2022-05-26	21420100-012DW22A	1.4	No
Classroom 23, Classroom Faucet	21420100-013CF	2022-05-26	21420100-013CF22A	1	No
Classroom 23, Drinking Water Fountain	21420100-014DW	2022-05-26	21420100-014DW22A	1.8	No
Kitchen, North Kitchen Faucet	21420100-015KF	2022-05-26	21420100-015KF22A	2	No
Kitchen, South Wall Kitchen Faucet	21420100-016KF	2022-05-26	21420100-016KF22A	<1	No
Kitchen, Left Kitchen Faucet of two	21420100-017KF	2022-05-26	21420100-017KF22A	1	No
Kitchen, Right Kitchen Faucet of two	21420100-018KF	2022-05-26	21420100-018KF22A	<1	No
Classroom 24, Classroom Faucet	21420100-019CF	2022-05-26	21420100-019CF22A	<1	No
Classroom 24, Drinking Water Fountain	21420100-020DW	2022-05-26	21420100-020DW22A	<1	No
Classroom 26, Classroom Faucet	21420100-021CF	2022-05-26	21420100-021CF22A	<1	No
Classroom 26, Drinking Water Fountain	21420100-022DW	2022-05-26	21420100-022DW22A	<1	No
Classroom 28, Drinking Water Fountain	21420100-023DW	2022-05-26	21420100-023DW22A	<1	No
Classroom 28, Classroom Faucet	21420100-024CF	2022-05-26	21420100-024CF22A	<1	No
Classroom 27, Classroom Faucet	21420100-025CF	2022-05-26	21420100-025CF22A	<1	No
Classroom 27, Drinking water Fountain	21420100-026DW	2022-05-26	21420100-026DW22A	<1	No

Classroom 25, Drinking Water Fountain	21420100-027DW	2022-05-26	21420100-027DW22A	<1	No
Classroom 25, Classroom Faucet	21420100-028CF	2022-05-26	21420100-028CF22A	<1	No
Staff Lounge 140, Staff Faucet	21420100-029SF	2022-05-26	21420100-029SF22A	<1	No
First Floor Hall at Cafeteria/Counseling Office, Left Drinking Water Fountain	21420100-030DW	2022-05-26	21420100-030DW22A	<1	No
First Floor Hall at Cafeteria/Counseling Office, Right Drinking Water Fountain	21420100-031DW	2022-05-26	21420100-031DW22A	<1	No
First Floor Hall at Cafeteria/Counseling Office, Water Bottle Filler	21420100-032WB	2022-05-26	21420100-032WB22A	<1	No
Classroom 30, Classroom Faucet	21420100-033CF	2022-05-26	21420100-033CF22A	<1	No
Classroom 30, Drinking Water Fountain	21420100-034DW	2022-05-26	21420100-034DW22A	<1	No
Classroom 32, Classroom Faucet	21420100-035CF	2022-05-26	21420100-035CF22A	<1	No
Classroom 32, Drinking Water Fountain	21420100-036DW	2022-05-26	21420100-036DW22A	<1	No
Classroom 34, Drinking Water Fountain	21420100-037DW	2022-05-26	21420100-037DW22A	<1	No
Classroom 34, Classroom Faucet	21420100-038CF	2022-05-26	21420100-038CF22A	<1	No
Classroom 33, Classroom Faucet	21420100-039CF	2022-05-26	21420100-039CF22A	<1	No
Classroom 33, Drinking Water Fountain	21420100-040DW	2022-05-26	21420100-040DW22A	<1	No
Classroom 31, Drinking Water Fountain	21420100-041DW	2022-05-26	21420100-041DW22A	<1	No
Classroom 31, Classroom Faucet	21420100-042CF	2022-05-26	21420100-042CF22A	1.4	No
Second Floor Hall at Cafeteria/Counseling Office, Left Drinking Water Fountain	21420100-043DW	2022-05-26	21420100-043DW22A	<1	No
Second Floor Hall at Cafeteria/Counseling Office, Right Drinking Water Fountain	21420100-044DW	2022-05-26	21420100-044DW22A	<1	No
Second Floor Hall at Cafeteria/Counseling Office, Water Bottle Filler	21420100-045WB	2022-05-26	21420100-045WB22A	<1	No
Classroom 16, Classroom Faucet	21420100-046CF	2022-05-26	21420100-046CF22A	<1	No
Classroom 16, Drinking Water Fountain	21420100-047DW	2022-05-26	21420100-047DW22A	3.8	No
Classroom 14, Classroom Faucet	21420100-048CF	2022-05-26	21420100-048CF22A	<1	No
Classroom 14, Drinking Water Fountain	21420100-049DW	2022-05-26	21420100-049DW22A	12.5	No
Hallway at Counseling 22, Drinking Water Fountain	21420100-050DW	2022-05-26	21420100-050DW22A	<1	No
LRC 10, Classroom Faucet	21420100-051CF	2022-05-26	21420100-051CF22A	9.4	No
LRC 10, Drinking Water Fountain	21420100-052DW	2022-05-26	21420100-052DW22A	2.6	No
Classroom 8, Drinking Water Fountain	21420100-053DW	2022-05-26	21420100-053DW22A	<1	No
Classroom 8, Classroom Faucet	21420100-054CF	2022-05-26	21420100-054CF22A	1.7	No
Hallway at Classroom 8, Drinking Water Fountain	21420100-055DW	2022-05-26	21420100-055DW22A	<1	No
Classroom 6, Drinking Water Fountain	21420100-056DW	2022-05-26	21420100-056DW22A	<1	No
Classroom 6, Classroom Faucet	21420100-057CF	2022-05-26	21420100-057CF22A	1.7	No
Classroom 4, Drinking Water Fountain	21420100-058DW	2022-05-26	21420100-058DW22A	<1	No
Classroom 4, Classroom Faucet	21420100-059CF	2022-05-26	21420100-059CF22A	3	No
Classroom 44, Classroom Faucet	21420100-060CF	2022-05-26	21420100-060CF22A	<1	No
Classroom 44, Drinking Water Fountain	21420100-061DW	2022-05-26	21420100-061DW22A	<1	No
Library MDF 83, Staff Faucet	21420100-062SF	2022-05-26	21420100-062SF22A	1.6	No

Classroom 2, Classroom Faucet	21420100-063CF	2022-05-26	21420100-063CF22A	2.3	No
Classroom 2, Drinking Water Fountain	21420100-064DW	2022-05-26	21420100-064DW22A	<1	No
Classroom 1, Classroom Faucet	21420100-065CF	2022-05-26	21420100-065CF22A	2.2	No
Classroom 1, Drinking Water Fountain	21420100-066DW	2022-05-26	21420100-066DW22A	1.1	No
Classroom 85, Classroom Faucet	21420100-067CF	2022-05-26	21420100-067CF22A	1.6	No
Classroom 85, Drinking Water Fountain	21420100-068DW	2022-05-26	21420100-068DW22A	<1	No
Classroom 71, Classroom Faucet	21420100-069CF	2022-05-26	21420100-069CF22A	<1	No
Classroom 71, Drinking Water Fountain	21420100-070DW	2022-05-26	21420100-070DW22A	<1	No
Classroom 70, Drinking Water Fountain	21420100-071DW	2022-05-26	21420100-071DW22A	<1	No
Classroom 70, Classroom Faucet	21420100-072CF	2022-05-26	21420100-072CF22A	<1	No
Hallway at Classroom 70, Drinking Water Fountain	21420100-073DW	2022-05-26	21420100-073DW22A	<1	No
Health Room/Temporary Staff Lounge 65, Staff Faucet	21420100-074SF	2022-05-26	21420100-074SF22A	<1	No
Classroom 64, Classroom Faucet	21420100-075CF	2022-05-26	21420100-075CF22A	<1	No
Classroom 64, Drinking Water Fountain	21420100-076DW	2022-05-26	21420100-076DW22A	<1	No
Classroom 3, Drinking Water Fountain	21420100-077DW	2022-05-26	21420100-077DW22A	<1	No
Classroom 3, Classroom Faucet	21420100-078CF	2022-05-26	21420100-078CF22A	1.8	No
Classroom 5, Drinking Water Fountain	21420100-079DW	2022-05-26	21420100-079DW22A	<1	No
Classroom 5, Classroom Faucet	21420100-080CF	2022-05-26	21420100-080CF22A	<1	No
Classroom 7, Drinking Water Fountain	21420100-081DW	2022-05-26	21420100-081DW22A	<1	No
Classroom 7, Classroom Faucet	21420100-082CF	2022-05-26	21420100-082CF22A	1.3	No
Classroom 9, Drinking Water Fountain	21420100-083DW	2022-05-26	21420100-083DW22A	<1	No
Classroom 9, Classroom Faucet	21420100-084CF	2022-05-26	21420100-084CF22A	1.8	No
Classroom 11, Classroom Faucet	21420100-085CF	2022-05-26	21420100-085CF22A	<1	No
Classroom 11, Drinking Water Fountain	21420100-086DW	2022-05-26	21420100-086DW22A	<1	No
ERC 13, Classroom Faucet	21420100-087CF	2022-05-26	21420100-087CF22A	<1	No
ERC 13, Drinking Water Fountain	21420100-088DW	2022-05-26	21420100-088DW22A	<1	No