

### Barrick Field - 2022 Lead in Drinking Water Sampling Results

<b>Inst. Name:</b>	Salem-Keizer Public Schools
<b>Inst. ID #:</b>	2142
<b>School Name:</b>	Barrick Field
<b>Building ID #:</b>	21420031

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Exterior of Restroom Building, Left Drinking Water Fountain	21420031-001DW	2022-05-20	21420031-001DW22A	<1	No
Exterior of Restroom Building, Right Drinking Water Fountain	21420031-002DW	2022-05-20	21420031-002DW22A	<1	No
Exterior of Restroom Building, Water Bottle Filler	21420031-003WB	2022-05-20	21420031-003WB22A	<1	No