

### Chavez Elementary School Childcare Fixtures - Drinking Water Sampling Results

|                       |                             |
|-----------------------|-----------------------------|
| <b>Inst. Name:</b>    | Salem-Keizer Public Schools |
| <b>Inst. ID #:</b>    | 5064                        |
| <b>School Name:</b>   | Chavez Childcare Facility   |
| <b>Building ID #:</b> | 21426500                    |

| Fixture ID # Coding          |  |                          |
|------------------------------|--|--------------------------|
| DW = Drinking Water Fountain |  | SF = Staff/Office Faucet |
| WC = Water Cooler (Chiller)  |  | KF = Kitchen/Food Prep   |
| WB = Water Bottle Filler     |  | IM = Ice Machine         |
| CF = Classroom Faucet        |  | SH = Shower Head         |
| BF = Bathroom Faucet         |  | OS = Outside Spigot      |
| NS = Nurse's Office Sink     |  | OT = Other (Specify)     |

| Fixture Location/Description                                | Fixture ID # (include coding from key above) | Sample Date | Sample ID         | Result (ppb) | Above Action Level (15 ppb) |
|---|--|-------------|-------------------|--------------|-----------------------------|
| Main Hall, Outside Workroom, Left Drinking Water Fountain   | 21426500-001DW                               | 2022-05-25  | 21426500-001DW22A | <1           | No                          |
| Main Hall, Near Workroom 192, Right Drinking Water Fountain | 21426500-002DW                               | 2022-05-25  | 21426500-002DW22A | <1           | No                          |
| Gym, Left Drinking Water Fountain                           | 21426500-003DW                               | 2022-05-25  | 21426500-003DW22A | <1           | No                          |
| Gym, Right Drinking Water Fountain                          | 21426500-004DW                               | 2022-05-25  | 21426500-004DW22A | <1           | No                          |
| Cafeteria, Left Drinking Water Fountain                     | 21426500-005DW                               | 2022-05-25  | 21426500-005DW22A | <1           | No                          |
| Cafeteria, Right Drinking Water Fountain                    | 21426500-006DW                               | 2022-05-25  | 21426500-006DW22A | <1           | No                          |