

Claggett Creek Middle School - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	Claggett Creek Middle School
Building ID #:	21424900

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Main Office	21424900-001-SF	2021-06-25	6252021-21424900-001-SF	2.98	No
Main Office	21424900-002-SF	2021-06-25	6252021-21424900-002-SF	3.14	No
Main Office - Isolation Room	21424900-003-DW	2021-06-25	6252021-21424900-003-DW	3.21	No
Main Office - Isolation Room	21424900-004-CF	2021-06-25	6252021-21424900-004-CF	4.44	No
Main Office - Health Room	21424900-005-NS	2021-06-25	6252021-21424900-005-NS	2.08	No
Room 112	21424900-006-DW	2021-06-25	6252021-21424900-006-DW	1.63	No
Room 112	21424900-007-CF	2021-06-25	6252021-21424900-007-CF	1.76	No
Room 113	21424900-008-CF	2021-06-25	6252021-21424900-008-CF	5.05	No
Hall at 114/Student Store/Exit	21424900-009-DW	2021-06-25	6252021-21424900-009-DW	<1	No
Hall at 114/Student Store/Exit	21424900-010-DW	2021-06-25	6252021-21424900-010-DW	<1	No
Room 114	21424900-011-DW	2021-06-25	6252021-21424900-011-DW	1.08	No
Room 114	21424900-012-DW	2021-06-25	6252021-21424900-012-DW	1.63	No
Room 115	21424900-013-DW	2021-06-25	6252021-21424900-013-DW	1.73	No
Room 115	21424900-014-CF	2021-06-25	6252021-21424900-014-CF	3.96	No
Gym at Far End	21424900-015-DW	2021-06-25	6252021-21424900-015-DW	1.57	No
Gym at Far End	21424900-016-DW	2021-06-25	6252021-21424900-016-DW	<1	No
Gym near 115	21424900-017-DW	2021-06-25	6252021-21424900-017-DW	<1	No
Gym near 115	21424900-018-DW	2021-06-25	6252021-21424900-018-DW	<1	No
Boy's locker room	21424900-019-DW	2022-02-02	222022-21424900-019-DW	<1	No
Boy's locker room	21424900-020-DW	2022-02-02	222022-21424900-020-DW	<1	No
Hall at Locker Rooms	21424900-021-DW	2021-06-25	6252021-21424900-021-DW	<1	No
Hall at Locker Rooms	21424900-022-DW	2021-06-25	6252021-21424900-022-DW	1.34	No
Girls Locker Room	21424900-023-DW	2021-06-25	6252021-21424900-023-DW	<1	No
Girls Locker Room	21424900-024-DW	2022-02-02	222022-21424900-024-DW	<1	No
Kitchen Dish Area	21424900-025-KF	2021-06-25	6252021-21424900-025-KF	2.38	No
Kitchen Dish Area	21424900-026-KF	2021-06-25	6252021-21424900-026-KF	19.3	Yes

Kitchen Dish Area - Resample	21424900-026-KF	2022-02-18	2182022-21424900-026-KF	7.2	No
Kitchen Prep	21424900-027-KF	2021-06-25	6252021-21424900-027-KF	3.92	No
Kitchen Prep (Produce)	21424900-028-KF	2021-06-25	6252021-21424900-028-KF	2.71	No
Room 118	21424900-029-SF	2021-06-25	6252021-21424900-029-SF	3.74	No
Room 111	21424900-030-CF	2021-06-25	6252021-21424900-030-CF	4.55	No
Room 111	21424900-031-CF	2021-06-25	6252021-21424900-031-CF	5.07	No
Room 111	21424900-032-CF	2021-06-25	6252021-21424900-032-CF	5.17	No
Room 111	21424900-033-CF	2021-06-25	6252021-21424900-033-CF	3.41	No
Room 111	21424900-034-CF	2021-06-25	6252021-21424900-034-CF	3.28	No
Room 111	21424900-035-CF	2021-06-25	6252021-21424900-035-CF	2.7	No
Room 111	21424900-036-CF	2021-06-25	6252021-21424900-036-CF	3.96	No
Room 110	21424900-037-DW	2021-06-25	6252021-21424900-037-DW	3.71	No
Room 110	21424900-038-CF	2021-06-25	6252021-21424900-038-CF	6.89	No
Room 109	21424900-039-CF	2021-06-25	6252021-21424900-039-CF	4.78	No
Room 108	21424900-040-CF	2021-06-25	6252021-21424900-040-CF	<1	No
Room 106	21424900-041-CF	2021-06-25	6252021-21424900-041-CF	<1	No
Room 104	21424900-042-SF	2021-06-25	6252021-21424900-042-SF	2.68	No
Room 103	21424900-043-DW	2021-06-25	6252021-21424900-043-DW	2.91	No
Room 103	21424900-044-CF	2021-06-25	6252021-21424900-044-CF	1.87	No
Room 102	21424900-045-DW	2021-06-25	6252021-21424900-045-DW	2.99	No
Room 102	21424900-046-CF	2021-06-25	6252021-21424900-046-CF	3.81	No
Room 100	21424900-047-DW	2021-06-25	6252021-21424900-047-DW	14	No
Room 100	21424900-048-CF	2021-06-25	6252021-21424900-048-CF	3.52	No
Room 209	21424900-049-CF	2021-06-25	6252021-21424900-049-CF	1.74	No
Room 208	21424900-050-DW	2021-06-25	6252021-21424900-050-DW	3.72	No
Room 208	21424900-051-CF	2021-06-25	6252021-21424900-051-CF	1.93	No
Room 207	21424900-052-DW	2021-06-25	6252021-21424900-052-DW	3.09	No
Room 207	21424900-053-CF	2021-06-25	6252021-21424900-053-CF	7.22	No
Room 206	21424900-054-DW	2021-06-25	6252021-21424900-054-DW	1.63	No
Room 206	21424900-055-CF	2021-06-25	6252021-21424900-055-CF	1.23	No
Staff Room 204	21424900-056-SF	2021-11-11	11112021-21424900-056-SF	1.9	No
Room 203	21424900-057-DW	2021-06-25	6252021-21424900-057-DW	1.77	No
Room 203	21424900-058-CF	2021-06-25	6252021-21424900-058-CF	1.53	No
Room 202	21424900-059-DW	2021-06-25	6252021-21424900-059-DW	2.85	No
Room 202	21424900-060-CF	2021-06-25	6252021-21424900-060-CF	2.92	No
Room 201	21424900-061-DW	2021-06-25	6252021-21424900-061-DW	4.91	No
Room 201	21424900-062-CF	2021-06-25	6252021-21424900-062-CF	1.66	No
Room 200	21424900-063-DW	2021-06-25	6252021-21424900-063-DW	2.51	No
Room 200	21424900-064-CF	2021-06-25	6252021-21424900-064-CF	5.17	No

Library Workroom	21424900-065-SF	2021-06-25	6252021-21424900-065-SF	1.65	No
Room 210	21424900-066-DW	2021-06-25	6252021-21424900-066-DW	1.66	No
Room 210	21424900-067-CF	2021-06-25	6252021-21424900-067-CF	3.64	No
Room 211	21424900-068-DW	2021-06-25	6252021-21424900-068-DW	1.54	No
Room 211	21424900-069-CF	2021-06-25	6252021-21424900-069-CF	1.18	No
Room 212	21424900-070-DW	2021-06-25	6252021-21424900-070-DW	2.45	No
Room 212	21424900-071-CF	2021-06-25	6252021-21424900-071-CF	2.63	No
Room 213	21424900-072-DW	2021-06-25	6252021-21424900-072-DW	4.56	No
Room 213	21424900-073-CF	2021-06-25	6252021-21424900-073-CF	2.12	No
Second Floor Hall at Band Room	21424900-074-DW	2022-02-02	222022-21424900-074-DW	<1	No
Second Floor Hall at Band Room	21424900-075-DW	2022-02-02	222022-21424900-075-DW	1.4	No
Choir Room 214	21424900-076-DW	2021-06-25	6252021-21424900-076-DW	<1	No
Choir Room 214	21424900-077-DW	2021-06-25	6252021-21424900-077-DW	<1	No
Band Room 215	21424900-078-DW	2021-06-25	6252021-21424900-078-DW	<1	No
Band Room 215	21424900-079-DW	2021-06-25	6252021-21424900-079-DW	<1	No
Staff Room 310	21424900-080-SF	2021-06-25	6252021-21424900-080-SF	3.09	No
Room 311	21424900-081-DW	2021-06-25	6252021-21424900-081-DW	7.3	No
Room 311	21424900-082-CF	2021-06-25	6252021-21424900-082-CF	9.36	No
Room 312	21424900-083-DW	2021-11-11	11112021-21424900-083-DW	1.4	No
Room 312	21424900-084-CF	2021-11-11	11112021-21424900-084-CF	1.2	No
Room 313	21424900-085-DW	2022-02-02	222022-21424900-085-DW	3	No
Room 313	21424900-086-CF	2021-06-25	6252021-21424900-086-CF	3.44	No
Room 314	21424900-087-DW	2021-06-25	6252021-21424900-087-DW	3.48	No
Room 314	21424900-088-CF	2021-06-25	6252021-21424900-088-CF	2.45	No
Room 316	21424900-089-DW	2021-06-25	6252021-21424900-089-DW	2.02	No
Room 316	21424900-090-CF	2021-06-25	6252021-21424900-090-CF	2.74	No
Third Floor Hall at 316	21424900-091-DW	2022-02-02	222022-21424900-091-DW	<1	No
Third Floor Hall at 316	21424900-092-DW	2021-06-25	6252021-21424900-092-DW	1.71	No
Room 317	21424900-093-DW	2021-06-25	6252021-21424900-093-DW	2.54	No
Room 317	21424900-094-CF	2021-06-25	6252021-21424900-094-CF	1.92	No
Room 318	21424900-095-CF	2021-06-25	6252021-21424900-095-CF	9.23	No
Room 318 Workroom	21424900-096-SF	2021-06-25	6252021-21424900-096-SF	4.86	No
Room 309 Storage	21424900-097-SF	2021-06-25	6252021-21424900-097-SF	7.82	No
Room 309	21424900-098-CF	2021-06-25	6252021-21424900-098-CF	5.25	No
Room 308	21424900-099-DW	2021-06-25	6252021-21424900-099-DW	1.21	No
Room 308	21424900-100-CF	2021-06-25	6252021-21424900-100-CF	2.51	No
Room 307	21424900-101-DW	2021-06-25	6252021-21424900-101-DW	1.49	No
Room 307	21424900-102-CF	2021-06-25	6252021-21424900-102-CF	3.09	No
Room 306	21424900-103-DW	2021-06-25	6252021-21424900-103-DW	3.25	No

Room 306	21424900-104-CF	2021-06-25	6252021-21424900-104-CF	4.04	No
Room 303	21424900-105-DW	2021-06-25	6252021-21424900-105-DW	3.14	No
Room 303	21424900-106-CF	2021-06-25	6252021-21424900-106-CF	1.93	No
Room 302	21424900-107-DW	2021-06-25	6252021-21424900-107-DW	1.23	No
Room 302	21424900-108-CF	2021-06-25	6252021-21424900-108-CF	2.03	No
Room 301	21424900-109-DW	2021-06-25	6252021-21424900-109-DW	3.97	No
Room 301	21424900-110-CF	2021-06-25	6252021-21424900-110-CF	4.3	No
Room 300	21424900-111-DW	2021-06-25	6252021-21424900-111-DW	1.95	No
Room 300	21424900-112-CF	2021-06-25	6252021-21424900-112-CF	3.25	No

Notes:

Fixtures that test above 15 ppb during the initial sampling event are taken out of service, repaired/replaced and then retested prior to returning to service.