

Clear Lake Elementary School - 2022 Lead in Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	734
School Name:	Clear Lake Elementary School
Building ID #:	21420500

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result in Parts Per Billion (ppb)	Above EPA Action Level (15 ppb)
Main Office, Health Room, Staff Faucet	21420500-001SF	2022-05-20	21420500-001SF22A	<1	No
Main Office, Health Room, Drinking Water Fountain	21420500-002DW	2022-05-20	21420500-002DW22A	<1	No
Staff Room, Staff Faucet	21420500-003SF	2022-05-20	21420500-003SF22A	<1	No
A Pod Commons, Classroom Faucet	21420500-004CF	2022-05-20	21420500-004CF22A	6.5	No
A Pod Commons, Drinking Water Fountain	21420500-005DW	2022-05-20	21420500-005DW22A	<1	No
Classroom A1, Classroom Faucet	21420500-006CF	2022-05-20	21420500-006CF22A	5.8	No
Classroom A1, Drinking Water Fountain	21420500-007DW	2022-05-20	21420500-007DW22A	<1	No
Classroom A2, Classroom Faucet	21420500-008CF	2022-05-20	21420500-008CF22A	<1	No
Classroom A2, Drinking Water Fountain	21420500-009DW	2022-05-20	21420500-009DW22A	<1	No
Classroom A3, Classroom Faucet	21420500-010CF	2022-05-20	21420500-010CF22A	4.9	No
Classroom A3, Drinking Water Fountain	21420500-011DW	2022-05-20	21420500-011DW22A	<1	No
Classroom A4, Classroom Faucet	21420500-012CF	2022-05-20	21420500-012CF22A	7.2	No
Classroom A4, Drinking Water Fountain	21420500-013DW	2022-05-20	21420500-013DW22A	<1	No
Classroom A5, Classroom Faucet	21420500-014CF	2022-05-20	21420500-014CF22A	5.6	No
Classroom A5, Drinking Water Fountain	21420500-015DW	2022-05-20	21420500-015DW22A	<1	No
Classroom A6, Classroom Faucet	21420500-016CF	2022-05-20	21420500-016CF22A	7	No
Classroom A6, Drinking Water Fountain	21420500-017DW	2022-05-20	21420500-017DW22A	<1	No
Library, Staff Faucet	21420500-018SF	2022-05-20	21420500-018SF22A	4.9	No
Library, Drinking Water Fountain	21420500-019DW	2022-05-20	21420500-019DW22A	<1	No
B Pod Commons, Classroom Faucet	21420500-020CF	2022-05-20	21420500-020CF22A	9	No
B Pod Commons, Drinking Water Fountain	21420500-021DW	2022-05-20	21420500-021DW22A	<1	No
Classroom B1, Classroom Faucet	21420500-022CF	2022-05-20	21420500-022CF22A	6.7	No
Classroom B1, Drinking Water Fountain	21420500-023DW	2022-05-20	21420500-023DW22A	<1	No
Classroom B2, Classroom Faucet	21420500-024CF	2022-05-20	21420500-024CF22A	10.2	No

Classroom B2, Drinking Water Fountain	21420500-025DW	2022-05-20	21420500-025DW22A	<1	No
Classroom B3, Classroom Faucet	21420500-026CF	2022-05-20	21420500-026CF22A	5.3	No
Classroom B3, Drinking Water Fountain	21420500-027DW	2022-05-20	21420500-027DW22A	<1	No
Classroom B4, Classroom Faucet	21420500-028CF	2022-05-20	21420500-028CF22A	5.9	No
Classroom B4, Drinking Water Fountain	21420500-029DW	2022-05-20	21420500-029DW22A	<1	No
Classroom B5, Classroom Faucet	21420500-030CF	2022-05-20	21420500-030CF22A	10.4	No
Classroom B5, Drinking Water Fountain	21420500-031DW	2022-05-20	21420500-031DW22A	<1	No
Classroom B6, Classroom Faucet	21420500-032CF	2022-05-20	21420500-032CF22A	7.8	No
Classroom B6, Drinking Water Fountain	21420500-033DW	2022-05-20	21420500-033DW22A	<1	No
Hallway between Library and C Pod at Restrooms, Drinking Water Fountain	21420500-034DW	2022-05-20	21420500-034DW22A	<1	No
C Pod Commons, Classroom Faucet	21420500-035CF	2022-05-20	21420500-035CF22A	<1	No
C Pod Commons, Drinking Water Fountain	21420500-036DW	2022-05-20	21420500-036DW22A	<1	No
Classroom C1, Classroom Faucet	21420500-037CF	2022-05-20	21420500-037CF22A	<1	No
Classroom C1, Drinking Water Fountain	21420500-038DW	2022-05-20	21420500-038DW22A	<1	No
Classroom C2, Classroom Faucet	21420500-039CF	2022-05-20	21420500-039CF22A	6.9	No
Classroom C2, Drinking Water Fountain	21420500-040DW	2022-05-20	21420500-040DW22A	<1	No
Classroom C3, Classroom Faucet	21420500-041CF	2022-08-11	21420500-041CF22B	1.4	No
Classroom C3, Drinking Water Fountain	21420500-042DW	2022-05-20	21420500-042DW22A	<1	No
Classroom C4, Classroom Faucet	21420500-043CF	2022-05-20	21420500-043CF22A	6	No
Classroom C4, Drinking Water Fountain	21420500-044DW	2022-05-20	21420500-044DW22A	<1	No
Classroom C5, Classroom Faucet	21420500-045CF	2022-05-20	21420500-045CF22A	11.8	No
Classroom C5, Drinking Water Fountain	21420500-046DW	2022-05-20	21420500-046DW22A	<1	No
Classroom C6, Classroom Faucet	21420500-047CF	2022-05-20	21420500-047CF22A	8.6	No
Classroom C6, Drinking Water Fountain	21420500-048DW	2022-05-20	21420500-048DW22A	<1	No
Classroom A7, Classroom Faucet	21420500-049CF	2022-05-20	21420500-049CF22A	8	No
Classroom A7, Drinking Water Fountain	21420500-050DW	2022-05-20	21420500-050DW22A	<1	No
Music Room, Classroom Faucet	21420500-051CF	2022-05-20	21420500-051CF22A	9.1	No
Music Room, Drinking Water Fountain	21420500-052DW	2022-05-20	21420500-052DW22A	<1	No
Hallway at Restrooms adjacent Cafeteria, Left Drinking Water Fountain	21420500-053DW	2022-05-20	21420500-053DW22A	<1	No
Hallway at Restrooms adjacent Cafeteria, Right Drinking Water Fountain	21420500-054DW	2022-05-20	21420500-054DW22A	<1	No
Cafeteria Southwest Closet, Staff Faucet	21420500-055SF	2022-05-20	21420500-055SF22A	<1	No
Kitchen, South Kitchen Faucet near Desk (with eyewash station)	21420500-056KF	2022-05-20	21420500-056KF22A	4.3	No
Gym, Drinking Water Fountain	21420500-057DW	2022-05-20	21420500-057DW22A	<1	No