

CTEC - 2021 Drinking Water Sampling Results

Inst. Name:	Salem-Keizer Public Schools
Inst. ID #:	N/A
School Name:	CTEC
Building ID #:	21420000

Fixture ID # Coding		
DW = Drinking Water Fountain		SF = Staff/Office Faucet
WC = Water Cooler (Chiller)		KF = Kitchen/Food Prep
WB = Water Bottle Filler		IM = Ice Machine
CF = Classroom Faucet		SH = Shower Head
BF = Bathroom Faucet		OS = Outside Spigot
NS = Nurse's Office Sink		OT = Other (Specify)

Fixture Location/Description	Fixture ID # (include coding from key above)	Sample Date	Sample ID	Result (ppb)	Above Action Level (15 ppb)
Main Office	21420000-001-SF	2021-06-23	6232021-21420000-001-SF	<1	No
Kitchen	21420000-002-KF	2021-06-23	6232021-21420000-002-KF	<1	No
Kitchen	21420000-003-KF	2021-06-23	6232021-21420000-003-KF	<1	No
Kitchen	21420000-004-IM	2021-06-23	6232021-21420000-004-IM	<1	No
Culinary Class	21420000-005-KF	2021-06-23	6232021-21420000-005-KF	<1	No
Culinary Class	21420000-006-KF	2021-06-23	6232021-21420000-006-KF	<1	No
Culinary Class	21420000-007-KF	2021-06-23	6232021-21420000-007-KF	<1	No
Culinary Class	21420000-008-KF	2021-06-23	6232021-21420000-008-KF	<1	No
Culinary Class	21420000-009-IM	2021-11-11	11112021-21420000-009-IM	<1	No
Culinary Class	21420000-010-KF	2021-06-23	6232021-21420000-010-KF	<1	No
Agriscience Lab Storage	21420000-011-CF	2021-06-23	6232021-21420000-011-CF	<1	No
Agriscience Lab Storage 2	21420000-012-CF	2021-06-23	6232021-21420000-012-CF	<1	No
Agriscience Lab	21420000-013-CF	2021-06-23	6232021-21420000-013-CF	<1	No
Agriscience Lab	21420000-014-CF	2021-06-23	6232021-21420000-014-CF	<1	No
Agriscience Room	21420000-015-CF	2021-06-23	6232021-21420000-015-CF	<1	No
Staff Lounge	21420000-016-SF	2021-06-23	6232021-21420000-016-SF	<1	No
Staff Lounge	21420000-017-SF	2021-06-23	6232021-21420000-017-SF	<1	No
Staff RR Area	21420000-018-DW	2021-11-11	11112021-21420000-018-DW	<1	No
Staff RR Area	21420000-019-DW	2021-11-11	11112021-21420000-019-DW	<1	No
Staff RR Area	21420000-020-WB	2021-06-23	6232021-21420000-020-WB	<1	No
Skills Room	21420000-021-DW	2021-11-11	11112021-21420000-021-DW	<1	No
Skills Room	21420000-022-DW	2021-11-11	11112021-21420000-022-DW	<1	No
Skills Room	21420000-023-WB	2021-06-23	6232021-21420000-023-WB	<1	No
Courtroom Class	21420000-024-CF	2021-06-23	6232021-21420000-024-CF	<1	No
Cosmetology RR Area	21420000-025-DW	2021-11-11	11112021-21420000-025-DW	<1	No
Cosmetology RR Area	21420000-026-DW	2021-11-11	11112021-21420000-026-DW	<1	No

Cosmetology RR Area	21420000-027-WB	2021-06-23	6232021-21420000-027-WB	<1	No
Salon Storage Area	21420000-028-CF	2021-06-23	6232021-21420000-028-CF	<1	No
Salon	21420000-029-CF	2021-06-23	6232021-21420000-029-CF	<1	No
Salon Classroom	21420000-030-CF	2021-06-23	6232021-21420000-030-CF	<1	No
Science Room	21420000-031-CF	2021-06-23	6232021-21420000-031-CF	<1	No
Staff Lounge	21420000-032-SF	2021-06-23	6232021-21420000-032-SF	<1	No
Cafe Restrooms	21420000-033-DW	2021-11-11	11112021-21420000-033-DW	<1	No
Cafe Restrooms	21420000-034-DW	2021-11-11	11112021-21420000-034-DW	<1	No
Cafe Restrooms	21420000-035-WB	2021-06-23	6232021-21420000-035-WB	<1	No
Fab Lab	21420000-036-CF	2021-06-23	6232021-21420000-036-CF	<1	No
Fab Lab	21420000-037-CF	2021-06-23	6232021-21420000-037-CF	<1	No
Auto Shop Classroom	21420000-038-CF	2021-06-23	6232021-21420000-038-CF	<1	No
Construction Restrooms	21420000-039-DW	2021-06-23	6232021-21420000-039-DW	<1	No
Manufacturing Restrooms	21420000-040-DW	2021-06-23	6232021-21420000-040-DW	<1	No
Studio - Next to Auto Shop	21420000-041-CF	2021-06-23	6232021-21420000-041-CF	<1	No
Studio - Next to Auto Shop	21420000-042-CF	2021-06-23	6232021-21420000-042-CF	<1	No